AMERICAN NATIONAL STANDARD

ANSI/ISA-5.1-2009

Instrumentation Symbols and Identification

Approved 18 September 2009

ANSI/ISA-5.1-2009, Instrumentation Symbols and Identification

ISBN: 978-1-936007-29-5

Copyright © 2009 by ISA. All rights reserved. Not for resale. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA 67 Alexander Drive P. O. Box 12277 Research Triangle Park, North Carolina, 27709 USA

Preface (informative)

This preface is included for information purposes and is not part of ANSI/ISA-5.1-2009.

This standard has been prepared as part of the service of ISA, The International Society of Automation, toward the goal of uniformity in the field of industrial automation. To be of continuing value, this standard should not be static but should be subject to periodic review. ISA welcomes all comments and suggestions and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone: (919) 549-8411; Fax: (919) 549-8288, e-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. Standard for Use of the International System of Units (SI): The Modern Metric System, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

CAUTION — ISA ADHERES TO THE POLICY OF THE AMERICAN NATIONAL STANDARDS INSTITUTE WITH REGARD TO PATENTS. IF ISA IS INFORMED OF AN EXISTING PATENT THAT IS REQUIRED FOR USE OF THIS STANDARD, IT WILL REQUIRE THE OWNER OF THE PATENT TO GRANT EITHER A ROYALTY-FREE LICENSE FOR USE OF THE PATENT BY USERS COMPLYING WITH THIS STANDARD OR A LICENSE ON REASONABLE TERMS AND CONDITIONS THAT ARE FREE FROM UNFAIR DISCRIMINATION.

EVEN IF ISA IS UNAWARE OF ANY PATENT COVERING THIS STANDARD, THE USER IS CAUTIONED THAT IMPLEMENTATION OF THIS STANDARD MAY REQUIRE USE OF TECHNIQUES, PROCESSES, OR MATERIALS COVERED BY PATENT RIGHTS. ISA TAKES NO POSITION ON THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS THAT MAY BE INVOLVED IN IMPLEMENTING THIS STANDARD. ISA IS NOT RESPONSIBLE FOR IDENTIFYING ALL PATENTS THAT MAY REQUIRE A LICENSE BEFORE IMPLEMENTATION OF THIS STANDARD OR FOR INVESTIGATING THE VALIDITY OR SCOPE OF ANY PATENTS BROUGHT TO ITS ATTENTION. THE USER SHOULD CAREFULLY INVESTIGATE RELEVANT PATENTS BEFORE USING THIS STANDARD FOR THE USER'S INTENDED APPLICATION.

HOWEVER, ISA ASKS THAT ANYONE REVIEWING THIS STANDARD WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THIS STANDARD NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

ADDITIONALLY, THE USE OF THIS STANDARD MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS, OR EQUIPMENT. THIS STANDARD CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS STANDARD MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS STANDARD.

THE USER OF THIS STANDARD SHOULD BE AWARE THAT THIS STANDARD MIGHT BE AFFECTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

Users may find the following book of value in applying ANSI/ISA-5.1-2009:

Control System Documentation: Applying Symbols and Identification, Thomas McAvinew www.isa.org/books.

Users of this standard are asked to send comments or suggestions to standards@isa.org.

The following served as voting members of the ISA5 Committee during development of ANSI/ISA-5.1-2009.

Name Affiliation

Alvin Iverson, Chair Ivy Optiks

lan Verhappen, Managing Director Industrial Automation Networks Inc

Thomas McAvinew, Past Managing Director Jacobs Engineering

James Carew, Chair, ISA5.1 Consultant

Gerald Barta Mustang Engineering LP

Donald Frey Reliatech Inc Alex Habib Consultant

Ganesier Ramachandran Shell Global Solutions US

On behalf of the ISA5 Committee and the ISA Standards & Practices Board, we wish to recognize and thank James Carew for his outstanding work, technical expertise, and commitment in leading the revision of this widely used ISA standard, and Thomas McAvinew for his valuable technical and editorial contributions.

Al Iverson, ISA5 Chair

Ian Verhappen, ISA5 Managing Director

The ISA Standards and Practices Board approved this standard on 23 July 2009

Name Affiliation

P. Brett Honeywell Inc. M. Coppler Ametek Inc.

E. Cosman The Dow Chemical Company

B. Dumortier Schneider Electric
D. Dunn Aramco Services Co.
R. Dunn DuPont Engineering

J. Gilsinn NIST/MEL E. Icayan ACES Inc.

J. Jamison Husky Energy Inc.

D. Kaufman Honeywell

K. P. Lindner Endress + Hauser Process Solutions AG


V. Maggioli Feltronics Corp.
T. McAvinew Jacobs Engineering

G. McFarland Emerson Process Mgmt. Power & Water Sol.

R. Reimer Rockwell Automation

N. Sands DuPont

H. Sasajima T. Schnaare I. Verhappen R. Webb W. Weidman J. Weiss M. Widmeyer M. Zielinski Yamatake Corp.
Rosemount Inc.
MTL Instrument Group
ICS Secure LLC
Worley Parsons
Applied Control Solutions LLC
Consultant
Emerson Process Management



Contents

1	Purpose	13				
2	Scope	13				
3	Definitions	17				
4	Identification letters table					
5	Graphic symbol tables					
6	Graphic symbol dimension tables					
Anne	85					
Anne	ex B Graphic symbol guidelines (informative annex)	111				
T = 1-1	la A.A. Haland Cantina Interna	00				
	le 4.1 — Identification letters					
	le 5.1.1 — Instrumentation device and function symbols					
	le 5.1.2 — Instrumentation device or function symbols, miscellaneous					
	le 5.2.1 — Measurement symbols: primary elements and transmitters					
	le 5.2.2 — Measurement symbols: measurement notations (4)					
	le 5.2.3 — Measurement symbols: primary elements					
	le 5.2.4 — Measurement symbols: secondary instruments					
	le 5.2.5 — Measurement symbols: auxiliary and accessory devices					
	le 5.3.1 — Line symbols: instrument to process and equipment connections					
	le 5.3.2 — Line symbols: instrument-to-instrument connections					
	e 5.4.1 — Final control element symbols					
Table	e 5.4.2 — Final control element actuator symbols	50				
Table	le 5.4.3 — Self-actuated final control element symbol	52				
Table	e 5.4.4 — Control valve failure and de-energized position indications	55				
Table	e 5.5 — Functional diagramming symbols	56				
Table	e 5.6 — Signal processing function block symbols	57				
Table	le 5.7 — Binary logic symbols	64				
Table	e 5.8 — Electrical schematic symbols	72				
Table	le 6.1 — Dimensions for Tables 5.1.1 and 5.1.2	78				
Table	le 6.2 — Dimensions for Tables 5.2.1, 5.2.2, 5.2.3, 5.2.4, and 5.2.5	79				
Table	le 6.3 — Dimensions for Tables 5.3.1 and 5.3.2	80				
Table	le 6.4 — Dimensions for Tables 5.4.1, 5.4.2, 5.4.3, and 5.4.4	81				
Table	le 6.5 — Dimensions for Table 5.5	82				
Table	le 6.6 — Dimensions for Table 5.6	82				
Table	le 6.7 — Dimensions for Table 5.7	83				
Table	le 6.8 — Dimensions for Table 5.8	84				
Table	le A.1 — Typical Loop and Instrument Identification/Tag Numbers	99				

Table A.2.1 — Allowable letter/number combinations for loop numbering schemes and first letters A to	
Table A.2.2 — Allowable letter/number combinations for loop numbering schemes and first letters P to VZZ	0
Table A.2.3 — Allowable letter/number combinations for loop numbering schemes and first letters W t ZDZ	
Table A.3.1.1 — Allowable succeeding letters for readout/passive functions aand ffirst letters A to O (4b)	
Table A.3.1.2 — Allowable succeeding letters for readout/passive functions and first letters P to VZZ ((4b)	. ,
Table A.3.1.3 — Allowable succeeding letters for readout/passive functions and first letters W to ZDZ (4b)	1. 1
Table A.3.2.1 — Allowable succeeding letters for output/active function letters and first letters A to O (4b2)	`
Table A.3.2.2 — Allowable succeeding letters for output/active function letters and first letters P to VZ (1) (4b2)	
Table A.3.2.3 — Allowable succeeding letters for output/active function letters and first letters W to ZE (1) (4b2)	
Table A.4 — Loop and Identification Tag Number suffixes (1) (2)	. 109

Introduction (informative)


- (1) This introduction, as well as any footnotes, endnotes, and informative annexes, is included for information purposes and as background on the evolution of this standard and not as a normative part of ANSI/ISA-5.1-2009.
- (2) The instrumentation symbolism and identification systems described in this standard accommodate advances in technology and reflect the collective industrial experience gained since the original ISA Recommended Practice RP-5.1, published in 1949, was revised, affirmed, and subsequently published as ANSI/ISA-5.1-1984, and then reaffirmed in 1992.
- (3) This 2009 version attempts to strengthen this standard in its role as a communication tool in all industries that depend on measurement and control systems to operate and safeguard their manufacturing processes, machines, and other equipment. Communication presupposes and is facilitated by a common language. This 2009 version of the standard continues to build on the foundation for that common language.
- (4) When integrated into a system, the designations and symbols presented here form a dedicated language that communicates concepts, facts, intent, instructions, and knowledge about measurement and control systems in all industries.
- (5) The 1949 recommended practice and the 1984 standard were published as non-mandatory rather than as mandatory consensus documents. As such, they had many of the strengths and the weaknesses of such standards. Their primary strength was that they could be used in widespread, interdisciplinary ways. Their main weakness was that they were not specific enough, in some cases, to satisfy the special requirements of particular interest groups.
- (6) This revision is published as a consensus standard and contains both mandatory and non-mandatory statements that have been reviewed and approved by a large group of practitioners in the field of instrumentation and control. This group was well versed in the use of identification and symbol systems as a means of communicating the intent of measurement and control systems to all that need such information. It is hoped that the consensus reached by this group regarding what is mandatory and what is not will enhance the strengths and lessen the weaknesses of the previous issues.
- (7) Versions of this standard have been in use for more than fifty years, and most of the identification letter and symbol meanings or definitions that were contained in ISA-RP5.1-1949 and ISA-5.1-1984 (R 1992), have taken on a proprietary nature and have become accepted industry practice and assumed to be mandatory. The meanings and definitions of new symbols will be mandatory. This action is being taken in response to questions and comments that occur frequently because of unclear definitions.
- (8) Mandatory definitions or meanings for letters used in identification and for symbols used in graphic depiction of measurement and control devices and functions are given. Mandatory minimum symbol dimensions are given. Informative identification and graphic symbol guidelines include alternate identification and symbol definitions and usage methods. Consistency is the one criterion that should govern the selection and application of identification and graphic schemes.
- (9) This standard has been viewed in the past as being oriented to the oil and chemical process industries. This perception, while not intended, resulted from the fact that people who wrote the original and previous revisions were mainly working in those industries. It is the intent of the ISA5 committee that ISA Technical Reports will be used to address this type of problem. It is hoped that the technical report format will be specific enough to satisfy the special requirements of particular interest groups by providing examples and guidelines for use of the identification and symbolization methods for specific industries. These industries include, but are not limited to, metal refining, power generation, pulp and paper, and discrete parts manufacturing. The technical report format presents the best approach for making this standard applicable to industries that may have many usages and accepted practices that are not used in

the process industries.

- (10) The extensive examples in previous versions of this standard that illustrated identification and symbolization definitions and methods have been removed and will be moved to technical reports that will be prepared after publication of this revised standard.
- (11) The symbols and identification methods contained in this standard have evolved by the consensus method and are intended for wide application throughout all industries. The symbols and designations are used as conceptualizing aids, as design tools, as teaching devices, and as a concise and specific means of communication in **all types and kinds** of technical, engineering, procurement, construction, and maintenance documents, and not just piping and instrumentation diagrams (P&IDs).
- (12) Previous versions of this standard have been flexible enough to serve all of the uses just described, and it must continue to do so into the future. To this end, this revision clarifies the definitions of symbols, identification, and definitions for concepts that were previously described, such as, for example, shared display/control, distributed control, and programmable control. It also adds definitions for new symbols required for functional diagramming of instruments and simple electrical circuit diagrams.
- (13) This revision extensively changes the format of ANSI/ISA-5.1-1984 (R 1992). Clauses 1, 2, and 3 are essentially the same as previously written with some additions and modifications. Clauses 4, 5 and 6 and informative Annexes A and B are new or extensively revised.
- (14) Clause 4, "Identification letter tables," was previously Clause 5, "Tables." It is almost the same as the previous version and deals only with Table 4.1, "Identification letters," which was previously Table 1, "Identification letters."
- (15) Clause 5, "Graphic symbol tables," is a new clause that contains new symbols and the symbols that were previously in Clause 6, "Drawings," presented in a table format that includes text describing the application of the symbols but no examples of their use.
- (16) Clause 6, "Graphic symbol dimension tables," is a new clause that establishes minimum mandatory dimensions for the symbols shown in the tables in Clause 5 when used in the preparation of full-size engineering drawings.
- (17) Annex A, "Identification system guidelines (Informative)," was previously Clause 4, "Outline of the Identification System," and presents the most commonly used instrumentation and function identification methods. Included are expanded "Allowable loop and function letter combination" tables and added "Allowable loop letter scheme" tables.
- (18) Annex B, "Graphic symbol guidelines" (Informative), is a new informative clause that replaces the examples formerly given in Clause 6, "Drawings," to provide some limited assistance in the application of the symbols in Clause 5.
- (19) Definitions for identification letters and symbols are now mandatory to reduce the confusion caused by giving meanings to identification and symbols not intended by this standard. At the same time, the number of symbology and tagging bubbles required to depict a measurement or control scheme was allowed to range from "everything must be shown" to the "minimum required to convey the instrumentation and functionality required." Guidelines are intended to aid in the application of identification and symbology and to include some of the known methods as alternate usages.
- (20) The meanings of 'shared display, shared control,' and 'programmable logic control' have been clarified and expanded because of changes in technology and usage since their inception in ISA-5.3-1983, "Graphic Symbols for Distributed Control/Shared Display Instrumentation, Logic and Computer Systems." The commonly assumed meanings of 'circle-in-square' as distributed control system (DCS) functions and of 'diamond-in-square' as programmable logic controller (PLC) functions are no longer

accurate because they no longer reflect the currently acceptable meanings. DCSs and PLCs can both perform continuous and binary control functions. The same functions are performed by personal computers (PC) and by fieldbus and devicebus devices. Both 'circle-in-square' and 'diamond-in-square' symbols are classified as 'shared display, shared control.' 'Circle-in-square' will depict either (a) primary control system choice or (b) basic process control system (BPCS). 'Diamond-in-square' will depict either (a) alternate control system choice or (b) safety instrumented system (SIS). Users who continue to use the symbols as in the past should change to the revised meanings as soon as possible.

- (21) This revision uses, with permission, information from the excellent SAMA (Scientific Apparatus Makers Association) PMC 22.1-1981, "Functional Diagramming of Instrument and Control Systems," a document still used by many control system engineers and designers. SAMA symbols and descriptions for functional diagramming of Instruments and control loops and for signal processing symbols and function blocks were adapted in ANSI/ISA-5.1-1984 (R 1992) for use in loop schematic diagrams. This revision adds the SAMA symbols and descriptions for logic function enclosures for use in functional diagrams, logic diagrams, and application software functions. Guidelines for a limited number of applications of the symbols will be found in Annex B, "Graphic symbol system guidelines (Informative)."
- (22) The binary line symbols, which were introduced in ANSI/ISA-5.1-1984 (R 1992) to aid the batch processing industries, have been removed because of their general lack of use and acceptance and the many objections to their use. If their use is desired within the batch processing industries, an ISA Technical Report could be produced to cover this unique need.
- (23) The many examples contained in Clause 6 of ANSI/ISA-5.1-1984 (R 1992) have been reduced in number and are now located in Annex B. It is hoped that ISA Technical Reports will be prepared based on this standard to cover the application of identification and symbolization methods and practices in the detail required by users in those many industries beyond the process industries, who depend on this standard in their daily work.
- (24) The ISA5 committee and ISA5.1 subcommittee recognize and deeply appreciate the work of previous ISA5.1 subcommittees, and have tried to treat their work with the great respect it deserves.
- (25) ISA5 and ISA5.1 also acknowledge the work done by the past ISA5.2 and ISA5.3 subcommittees in developing ISA-5.2-1976 (R1992), "Binary Logic Diagrams for Process Operations," and ISA-5.3-1983, "Graphic Symbols for Distributed Control/Shared Display Instrumentation, Logic and Computer Systems." The key elements of ISA-5.3-1983 were incorporated in ANSI/ISA-5.1-1984 (R 1992) and have been expanded in this revision. The key elements of ISA-5.2-1976 are incorporated and integrated with the logic symbols from SAMA PMC 22.1-1981 for symbolizing and describing binary functions. Guidelines for the application of the binary system can be found in Annex B (Informative), Graphic symbol system guidelines.



1 Purpose

This standard establishes a uniform means of depicting and identifying instruments or devices and their inherent functions, instrumentation systems and functions, and application software functions used for measurement, monitoring, and control, by presenting a designation system that includes identification schemes and graphic symbols.

2 Scope

2.1 General

- 2.1.1 This standard is intended to meet the different procedures of various users who need to identify and graphically depict measurement and control equipment and systems. These differences are recognized when they are consistent with the objectives of this standard, by providing alternative symbol and identification methods.
- 2.1.2 A limited number of examples are provided that illustrate how to:
 - a) Design an identification system and construct an identification number.
 - b) Use graphic symbols to construct:
 - 1) Instrumentation schematic diagrams of the instruments, devices, and functions required for monitoring and control loops.
 - 2) Functional diagrams of instruments, loops, and application software functions.
 - 3) Binary logic diagrams.
 - 4) Ladder diagrams of electrical circuits.
 - c) Add information and simplify diagrams.
- 2.1.3 Examples of identification and symbol applications are intended to illustrate basic concepts in the construction of the identification systems and diagrams covered by this standard that are applicable to all user industries.

2.2 Application to industries

2.2.1 This standard is suitable for use in the chemical, petroleum, power generation, metal refining, pulp and paper, and numerous other continuous, batch, discrete-part processing, and material-handling industries. These industries and others require the use of control system schematics, functional diagrams, and electrical schematics to describe the relationship to processing equipment and the functionality of measurement and control equipment.

- 2.3 Application to work activities
- 2.3.1 This standard is suitable for use whenever reference to measurement and control instrumentation, control devices and functions, and software applications and functions is required for identification and symbolization, such as:
 - a) Design sketches.
 - b) Teaching examples.
 - c) Technical papers, literature, and discussions.
 - d) Instrumentation, loop, logic, and functional diagrams.
 - e) Function descriptions.
 - f) Conceptual drawings including but not limited to:
 - 1) Process Flow Diagrams (PFD)
 - 2) Utility Flow Diagrams (UFD).
 - g) Construction drawings including but not limited to:
 - 1) Engineering Flow Diagrams (EFD).
 - 2) Mechanical Flow Diagrams (MFD).
 - 3) Piping and Instrumentation Diagrams (P&ID).
 - 4) System Flow Diagrams (SFD).
 - h) Specifications, purchase orders, manifests, and other lists.
 - i) Identification and tag numbering of instruments and control functions.
 - j) Installation, operating and maintenance instructions, drawings, and records.
- 2.3.2 This standard provides sufficient information to enable anyone who has a reasonable amount of process and instrumentation knowledge, and who is reviewing documents depicting measurement and control, to understand the means and purpose of the instrumentation shown.
- 2.3.3 The detailed knowledge of a specialist in instrumentation and/or control systems is not a prerequisite to understanding this standard.
- 2.4 Application to classes of instrumentation and to instrument functions
- 2.4.1 The identification and symbolism methods provided in this standard are applicable to all classes and types of measurement and control instruments and/or functions.
- 2.4.2 The methods can be used for, but are not limited to, describing and identifying:
 - a) Discrete instruments and their functions.

- b) Shared display and control functions.
- c) Distributed control functions.
- d) Computer control functions.
- e) Programmable logic controller display and control functions.
- f) Application software display and control functions.

2.5 Classification of instrumentation

- 2.5.1 Instrumentation may be classified as primary, secondary, auxiliary, or accessory for assigning Loop and Functional Identities and symbols as defined in Clause 4 and shown in Annex A.
- 2.5.2 Primary instrumentation consists of measuring, monitoring, controlling, or calculating devices and hardware and their inherent functions and software functions that include, but are not limited to, transmitters, recorders, controllers, control valves, self-actuated safety and control devices, and application software functions that require or allow user-assigned identifications.
- 2.5.3 Secondary instrumentation consists of measuring, monitoring, or controlling devices and hardware that include, but are not limited to, level glasses, pressure gauges, thermometers, and pressure regulators.
- 2.5.4 Auxiliary instrumentation consists of devices and hardware that measure, control, or calculate and that are needed for effective operation of primary or secondary instrumentation; they include, but are not limited to, calculating devices, purge meters, sample handling systems, and instrument air sets.
- 2.5.5 Accessory instrumentation consists of devices and hardware that do not measure or control but are needed for effective operation of the measuring, monitoring, or control system; they include, but are not limited to, flowmeter tube run, straightening vanes, and seal pots.
- 2.6 Extent of loop and functional identification
- 2.6.1 This standard provides identification codes and methods for the alphanumeric identification of monitoring and controlling loops, instruments and functions.
- 2.6.2 These identification methods depend on tagging according to function and not according to construction or form. For example, a differential pressure transmitter is not identified as a differential pressure transmitter but as a:
 - a) Flow transmitter when connected to an orifice plate when measuring flow.
 - b) Level transmitter when connected to the side of a vessel when measuring liquid level.
- 2.6.3 The user is free to apply added identification by serial, equipment, unit, area, or plant number, or any other additional means required for the unique identification of a loop, instrument or function.
- 2.6.4 A unique function identification number shall be assigned to identify each:
 - a) Loop instrument or device and its integral and/or inherent functions.

- b) Loop-configurable function, which requires or allows a unique user-assigned microprocessor or computer address.
- 2.7 Extent of symbolization
- 2.7.1 This standard provides symbol sets for the graphic depiction of a limited or total functionality of instruments and devices, entire monitor or control loops, or control circuits.
- 2.7.2 The amount of detail to be shown by the use of symbols depends on the purpose and audience for which the document is being prepared.
- 2.7.3 Sufficient symbols shall be used to show the functionality of the instrumentation and/or control loop being depicted; it is not considered necessary to provide a symbol for each instrument device and each function required by a loop.
- 2.7.4 Additional construction, fabrication, installation, and operation details of an instrument are better described in a suitable specification, data sheet, loop diagram, installation/wiring drawing, or sketch, or other document intended for those requiring such details.
- 2.8 Inclusion and modification of this standard in User engineering and design documents
- 2.8.1 This standard may be used and, if used, shall be credited by a User/Owner in the preparation of engineering, design, or project standards, guidelines, and specifications, either without exception or with exception per the following:
 - a) Without exception, in which case this standard in its entirety shall be mandatory with respect to:
 - 1) Letters assigned a specific meaning in Table 4.1.
 - 2) Symbols and their assigned meanings in Tables.5.1 through 5.8.
 - 3) Symbol dimensions in Tables 6.1 through 6.8.
 - b) With exceptions, in which case the parts of this standard for which exception is:
 - 1) Taken shall be fully described and detailed in the User/Owner standards, guidelines, or specifications and in drawing cover sheet legends and notes.
 - 2) Not taken shall be mandatory.
- 2.8.2 Symbols different from those given in this standard and User's choice letters when used, shall be fully described and detailed in the User/Owner's standards, guidelines, or specifications and in drawing cover sheet legends and notes.
- 2.8.3 A User must choose a numbering scheme, graphic symbol, and other choices where required, and document those choices.
- 2.8.4 When a previous issue of this standard is included by reference with or without exception in User/Owner's engineering and design standards, guidelines or specifications, that standard in part or in its entirety shall be mandatory until such time as the User/Owner's guidelines or standards are revised.

2.8.5 Symbols and the meanings of letters and symbols from previous versions of this standard that are different from those contained in this version may continue to be used provided they are clearly referenced in the User's engineering and design standards, practices, and/or guidelines.

3 Definitions

3.1 Definitions

For the purposes of this standard, the following definitions apply. For additional information, see ISA-51.1-1979 (R 1993), "Process Instrumentation Terminology," and ANSI/ISA-75.05.01-2000 (R 2005), "Control Valve Terminology." Terms *italicized* in a definition are themselves defined elsewhere in this clause.

3.1.1 accessible:

a feature of a *device* or function, a feature of an interactive shared system function, or a feature that can be used or seen by an operator for the purpose of performing control operations, such as *setpoint* changes, auto-manual transfer, or on-off operations.

3.1.2 alarm:

an indicating device or function that provides a visible and/or audible indication if and when the value of a measured or initiating variable is outside of set limits, has changed from a safe to an unsafe condition, or has changed from a normal to an abnormal operating state or condition.

- a) actuation may be by a binary or analog device or function.
- b) indication may be by any or all of the following: annunciator *panels*, flashing lights, printers, buzzers, bells, horns, sirens, or shared graphic display systems.

3.1.3 analog:

a signal or *device* that has no *discrete* positions or states and changes value as its input changes value and when used in its simplest form, as in "*analog* signal" as opposed to "*binary* signal"; the term denotes a continuously varying quantity.

3.1.4 application software:

software specific to a user application that is *configurable* and in general contains logic sequences, permissive and limit expressions, control algorithms, and other code required to control the appropriate input, output, calculations, and decisions; see also *software*

3.1.5 assignable:

a system feature permitting channeling or directing of a signal from one *device* to another without the need for changes in wiring either by means of patching, switching, or via keyboard commands to the system.

3.1.6 auto-manual station:

a *manual loading station* or *control station* that also provides switching between manual and automatic control modes of a control *loop*; see also manual station.

3.1.7 balloon:

an alternate term for the circular symbol used to denote and identify the purpose of an *instrument* or *function* that may contain a tag number; see preferred term *bubble*.

3.1.8 basic process control system (BPCS):

instrumentation and systems that are installed to monitor and control normal production operations using, but not limited to combinations of single-loop pneumatic and electronic monitors and controllers, programmable logic controllers and distributed control systems.

(a) A BPCS is necessary to operate a plant or process.

3.1.9 behind the panel:

a location that in a broad sense means "not normally accessible to an operator," such as the rear of an instrument or control *panel*, an enclosed instrument rack or cabinet, or an instrument rack room within an area that contains a *panel*.

3.1.10 binary:

a signal or *device* that has only two *discrete* positions or states, and when used in its simplest form, as in "*binary* signal" as opposed to "*analog* signal," the term denotes an "on-off" or "high-low" state.

3.1.11 board:

a freestanding structure consisting of one or more sections, cubicles, or consoles that has groups of discrete instruments mounted on it, houses the operator-process interface, and is chosen to have a unique designation; see panel.

3.1.12 bubble:

the preferred term for the circle-based symbols used to denote and identify the purpose of an *instrument* or function that may contain a tag number; see alternate term *balloon*.

3.1.13 communication link:

a wire, cable, or electromagnetic network or bus system that connects dedicated microprocessor-based and computer-based systems so that they share a common database, and communicates according to a rigid protocol in a hierarchical and/or peer-to-peer relationship; see *datalink*.

- a) wire or cable networks may be twisted pair, coaxial, telephone, or fiber optic.
- b) electromagnetic networks may be radio or microwave.

3.1.14 computer control system:

a system in which all control action takes place within a control computer, such as a mainframe computer or mini-computer, which may be single or redundant.

3.1.15 computing device:

the preferred term for a *device* that performs one or more calculations or logic operations, or both, and transmits one or more resultant output signals; see also *computing relay*.

3.1.16 computing relay:

an alternate term for a *device* that performs one or more calculations or logic operations, or both, and transmits one or more resultant output signals; see also *computing* device.

3.1.17 computing function:

a *hardware* or *software* function that performs one or more calculations or logic operations, or both, and transmits one or more resultant output signals.

3.1.18 configurable:

a term for devices or systems whose functional and/or communication characteristics can be selected or rearranged through setting of program switches, application software, fill-in-the-blank forms, pull-down menus, entered values or text, and/or other methods, other than rewiring as a means of altering the configuration.

3.1.19 controller:

a device having an output that varies to regulate a controlled variable in a specified manner that may be a self-contained analog or digital instrument, or may be the equivalent of such an instrument in a shared-control system.

- a) an automatic *controller* varies its output automatically in response to a direct or indirect input of a measured *process variable*.
- b) a manual *controller*, or *manual loading station*, varies its output in response to a manual adjustment; it is not dependent on a measured *process variable*.
- c) a *controller* may be an integral element of other functional elements of a control *loop*.

3.1.20 control station:

a manual loading station that also provides switching between manual and automatic control modes of a control loop; see also auto-manual station.

a). the operator interface of a distributed control system may be referred to as a control station.

3.1.21 control valve:

- a *device*, other than a common, hand-actuated *process* block valve or self-actuated check valve, that directly manipulates the flow of one or more fluid *process* streams.
- a) the designation "hand *control valve*" shall be limited to hand-actuated valves that when used for *process* throttling require *identification* as an *instrument* or control *device*.

3.1.22 converter:

a *device* that receives information as one form of an *instrument* signal and transmits an output signal as another form, such as a current-to-pneumatic signal *converter*.

a). an *instrument* that changes a *sensor*'s output to a standard signal, is properly designated as a *transmitter*, not a *converter*, typically, a temperature element [TE] connects to a *transmitter* [TT], not to a *converter* [TY].

b) a converter is sometimes referred to as a transducer, a completely general term not recommended for signal conversion.

3.1.23 datalink:

a wire, cable, or electromagnetic network or bus system that connects field-located *devices* with dedicated microprocessors so that they share a common database and communicate according to a rigid protocol in a hierarchical and/or peer-to-peer relationship to other such *devices* and/or compatible microprocessor-based systems; see also *communication link*.

- a) wire or cable networks may be twisted pair, coaxial, telephone, or fiber optic.
- b) electromagnetic networks may be radio or microwave.

3.1.24 detector:

a *device* that is used to detect the presence of something, such as flammable or toxic gases or *discrete* parts; see also *primary element* and *sensor*.

3.1.25 device:

a piece of *instrument hardware* that is designed to perform a specific action or function, such as a *controller*, indicator, *transmitter*, annunciator, or *control valve*.

3.1.26 digital:

a signal or *device* that generates or uses *binary* digit signals to represent continuous values or *discrete* states.

3.1.27 discrete instrument

a device or hardware that has a separate entity, such as a single-case controller or recorder.

3.1.28 discrete signals:

signals that have any number of non-continuous distinct or defined states or positions.

a) Binary signals are a subset.

3.1.29 distributed control system (DCS):

instrumentation, input/output *devices*, control *devices* and operator interface *devices*, which in addition to executing stated control and indication functions, also permit transmission of control, *measurement*, and operating information to and from single or multiple-user specifiable locations, connected by single or multiple *communication links*.

3.1.30 field instrument:

an *instrument* that is not mounted on a *panel* or console or in a control room but commonly in the vicinity of its *primary element* or *final control element*, see local *instrument*.

3.1.31 final control element:

a *device*, such as a *control valve*, that directly controls the value of the manipulated variable of a control *loop*.

3.1.32 function:

the purpose of, or the action performed by, a device or application software.

3.1.33 hardware:

physical equipment directly involved in performing measuring, monitoring, and controlling functions.

3.1.34 high level control system (HLCS):

A system that provides sophistication above that of the BPCS; with *functions* typically based in process computer or higher level hardware that interacts with the process by manipulating setpoints in the BPCS.

- (a) Control *functions* in the HLCS include, but are not limited to, statistical process control and model predictive control.
- (b) An HLCS is not necessary to operate a plant or process.

3.1.35 identification:

the sequence of letters or numerals, or both, used to designate an individual instrument, function, or loop.

3.1.36 instrument:

- a device used for direct or indirect measurement, monitoring, and/or control of a variable, including primary elements, indicators, controllers, final control elements, computing devices, and electrical devices such as annunciators, switches, and pushbuttons.
- a) the term does not apply to a *devices* internal components or parts, such as receiver bellows or resistors.

3.1.37 instrumentation:

a collection of instruments, *devices*, *hardware*, or *functions* or their application for the purpose of measuring, *monitor*ing, or controlling an industrial *process* or machine, or any combination of these.

3.1.38 local instrument:

an instrument that is not mounted on a *panel* or console or in a control room, but commonly in the vicinity of its *primary element* or *final control element*, see *field instrument*.

3.1.39 local panel:

a *panel* that is not a central or main *panel* and is commonly located in the vicinity of plant subsystems or sub-areas.

a) the term "local panel instrument" should not be confused with "local instrument".

3.1.40 loop:

instrumentation arranged as a combination of two or more instruments or *functions* arranged so that signals pass from one to another for the purpose of *measurement* and indication or control of a *process* variable.

a) a self-contained *device* that measures and controls a *process variable*.

3.1.41 manual loading station:

a *device* or *function* that has a manually adjustable output, and may also have indicators, lights, and/or other *functions*, that is used to actuate and/or modulate one or more *devices*, but does not provide *switch*ing between auto-manual modes of a control *loop*.

3.1.42 measurement:

the determination of the existence and/or magnitude of a process variable.

3.1.43 monitor:

a general term for an instrument or instrument system used to measure or sense the status or magnitude of one or more variables for the purpose of deriving useful information, and that sometimes means analyzer, indicator, or *alarm*.

3.1.44 monitor light:

a light that indicates which of a number of normal, but not abnormal, conditions of a system or *device* exists; see also *pilot light*.

3.1.45 panel:

a freestanding or built-in structure consisting of one or more sections, cubicles, consoles, or desks that has groups of instrument *hardware* mounted on it, houses the operator-*process* interface, and is given a unique designation.

3.1.46 *panel*-mounted:

an instrument or other *device* that is mounted on a *panel* or console and is *accessible* for an operator's normal use.

a) a function that is normally accessible to an operator in a shared-display system is the equivalent of a discrete panel-mounted device.

3.1.47 pilot light:

a light that indicates which of a number of normal conditions of a system or *device* exists; it is not an *alarm* light, which indicates an abnormal condition. See also *monitor light*.

3.1.48 primary element:

an external or internal instrument or system element that quantitatively converts the measured variable into a form suitable for *measurement*, see also *detector* and *sensor*.

- a) an orifice plate is an external *primary element*
- b) the sensor of a transmitter is an internal primary element.

3.1.49 process:

any operation or sequence of operations involving a change of energy, state, composition, dimension, or other properties that may be defined with respect to zero or some other defined initial value.

3.1.50 process variable:

any measurable property of a *process*; used in this standard to apply to all variables other than instrument signals between *devices* in a *loop*.

3.1.51 program:

a repeatable sequence of actions that defines the state of outputs as a fixed relationship to the state of inputs.

3.1.52 programmable logic *controller*.

a *controller*, usually with multiple inputs and outputs, that contains an alterable *program* that is typically used to control *binary* and/or *discrete* logic or sequencing *functions*, and may also be used to provide continuous control *functions*.

3.1.53 relay:

a *device*, whose *function* is to pass on information in an unchanged form or in some modified form, often used to mean the preferred term *computing* device.

a) relay is a term applied specifically to an electric, pneumatic, or hydraulic switching device that is actuated by a signal, and to functions performed by a relay.

3.1.54 safety instrumented system:

a system composed of *sensors*, logic solvers, and *final control element*s for the purpose of taking the process to a safe state when pre-determined conditions are violated.

3.1.55 scan:

to sample, in a predetermined manner, each of a number of variables periodically or intermittently.

a) a scanning device is often used to ascertain the state or value of a group of variables, and may be associated with other functions such as recording and alarming.

3.1.56 sensor:

a separate or integral part or *function* of a *loop* or an instrument that first senses the value of a *process variable*, that assumes a corresponding predetermined and intelligible state, and/or generates an output signal indicative of or proportional to the *process variable*; see also *detector* and *primary element*.

3.1.57 setpoint:

an input variable that sets the desired value of the controlled variable manually, automatically, or by means of a *program* in the same units as the controlled variable.

3.1.58 shared control:

a feature of a control *device* or *function* that contains a number of pre-programmed algorithms, which are user retrievable, *configurable*, and connectable, and allows user-defined control strategies or *functions* to be implemented,

a) often used to describe the control features of a *distributed control system, programmable logic controller,* or other microprocessor or mainframe computer based system.

b) control of multiple *process variables* can be implemented by sharing the capabilities of a single *device* of this kind.

3.1.59 shared display:

the operator interface device, a video, light-emitting diode, liquid crystal, or other display unit, used to display process control information from a number of sources at the command of the operator, often used to describe the visual features of a distributed control system, programmable logic controller, or other microprocessor or mainframe computer based system.

3.1.60 software:

the *programs*, codes, procedures, algorithms, patterns, rules, and associated documentation required for the operation or maintenance of microprocessor or computer systems; see also *application software*.

3.1.61 software link:

the interconnection of system components via communication networks or *functions* via *software* or key*board* instruction.

3.1.62 supervisory setpoint control system:

the generation of setpoint and/or other control information by a computer control system for use by shared control, shared display or other regulatory control devices.

3.1.63 switch:

a *device* that connects, disconnects, selects, or transfers one or more circuits and is not designated as a *controller*, a *relay*, or a *control valve*; the term is also applied to the *functions* performed by *switches*.

3.1.64 test point:

a process connection to which no *instrument* is permanently connected, but which is intended for the temporary or intermittent connection of an *instrument*.

3.1.65 transducer:

a general term for a *device*, which can be a *primary element*, *transmitter*, *relay*, *converter* or other *device*, that receives information in the form of one or more physical quantities, modifies the information or its form, or both if required, and produces a resultant output signal.

3.1.66 transmitter:

a *device* that senses a *process variable* through the medium of a *sensor* or measuring element and has an output whose steady-state value varies only as a predetermined *function* of the *process variable*.

a) the *sensor* can be an integral part, as in a direct-connected pressure *transmitter*, or a separate part, as in a thermocouple.

4 Identification letters table

4.1 Identification letters table

- 4.1.1 This clause provides in tabular form the alphabetic building blocks of the Instrument and Function Identification System in a concise, easily referenced manner.
- 4.1.2 Table 4.1, together with Clause 4.2, defines and explains the meanings of the individual letters when used to identify loop and device functions.
- 4.1.3 The letters in Table 4.1 shall have the mandatory meanings assigned except the user shall assign:
 - a) Variables to the User's Choice letters in column 1 and functions to the User's Choice letters in columns 3, 4 and 5 when such letters are used.
 - b) Meanings to the blanks in columns 2, 3, 4, and 5 when additional functions or modifiers are assigned.
 - c) When such assignments are made they shall be documented in the User's engineering and design standards or guidelines and on drawing legend sheets.

4.2 Table 4.1 — Identification letters explanatory notes

The following notes, indicated in Table 4.1 by parentheses, are to be used as an aid in understanding the meanings of the letters when they are used in certain positions in Loop Identification Letter(s) or Functional Identifications.

- (1) First Letters are a Measured/Initiating Variable and, if required, a combination of a Measured/Initiating Variable and a Variable Modifier that shall be referred to by the combined meaning.
- The specific meanings given for Measured/Initiating Variables [A], [B], [E], [F], [H], [I], [J], [K] [L], [P], [Q], [R], [S], [T], [U], [V], [W], [Y], and [Z] shall not be modified.
- (3) Measured/Initiating Variable analysis [A] shall be used for all types of process stream composition and physical property analysis. The type of analyzer, and for stream component analyzers the components of interest, shall be defined outside the tagging bubble.
 - (a) "User's Choice" Measured/Initiating Variables [C], [D], and [M] are assigned to identify conductivity, density, and moisture analysis, respectively, when it is the user's common practice.
- (4) Measured/Initiating Variable analysis [A] shall not be used to identify vibration or other types of mechanical or machinery analysis, which shall be identified by Measured/Initiating Variable vibration or mechanical analysis [V].
- (5) "User's Choice" letters [C], [D], [M], [N], and [O] that cover unlisted repetitive meanings that may have one meaning as a Measured or Initiating Variable and another as a Succeeding-Letter shall be defined only once. For example, [N] may be defined as "modulus of elasticity" as a Measured/Initiating Variable and "oscilloscope" as a Readout/Passive Function.
- (6) Measured/Initiating Variable multivariable [U] identifies an instrument or loop that requires multiple points of measurement or other inputs to generate single or multiple outputs, such as a PLC that uses multiple pressure and temperature measurements to regulate the switching of multiple on-off valves.

- (7) Measured/Initiating Variable vibration or mechanical analysis [V] is intended to perform the function in machinery monitoring that Measured/Initiating Variable analysis [A] performs in process monitoring and except for vibration, it is expected that the variable of interest will be defined outside the tagging bubble.
- (8) First-Letter or Succeeding-Letter for unclassified devices or functions [X] for non-repetitive meanings that are used only once or to a limited extent may have any number of meanings that shall be defined outside the tagging bubble or by a note in the document. For example, [XR-2] may be a stress recorder and [XX-4] may be a stress oscilloscope.
- (9) Measured/Initiating Variable event, state, or presence [Y] is intended for use when control or monitoring responses are not driven by time or time schedule--but driven by events, presence, or state.
- (10) Measured/Initiating Variable and Variable Modifier combinations shall be selected according to how the property being measured is modified or changed.
- (11) Direct measured variables that shall be considered as Measured/Initiating Variables for Loop Numbering shall include but are not limited to:
 - (a) Differential [D] pressure [PD] or temperature [TD].
 - (b) Total [Q] flow totalizer [FQ], when directly measured, such as by a positive displacement flowmeter.
 - (c) X-axis, y-axis, or z-axis [X], [Y], or [Z] vibration [VX], [VY], and [VZ], force [WX], [WY], or [WZ] or position [ZX], [ZY], or [ZZ].
- (12) Derived or calculated from other direct measured variables that should not be considered as Measured/Initiating Variables for Loop Numbering shall include but are not limited to:
 - (a) Difference [D] temperature [TD] or weight [WD].
 - (b) Ratio [F] Flow [FF], pressure [PF], or temperature [TF].
 - (c) Time rate of change [K] pressure [PK], temperature [TK], or weight [WK].
- (13) Variable Modifier time or time schedule [K] in combination with a Measured/Initiating Variable signifies a time rate of change of the measured or initiating variable; [WK], represents a rate-of-weight-loss loop.
- (14) Variable Modifier safety [S] is technically not a direct-measured variable but is used to identify self-actuated emergency protective primary and final control elements only when used in conjunction with Measured/Initiating Variables flow [F], pressure [P] or temperature [T]. And because of the critical nature of such devices, [FS, PS, and TS] shall be considered as Measured/ Initiating Variables in all Loop Identification Number construction schemes:
 - (a) Flow safety valve [FSV] applies to valves intended to protect against an emergency excess flow or loss of flow condition. Pressure safety valve [PSV] and temperature safety valve [TSV] apply to valves intended to protect against emergency pressure and temperature conditions. This applies regardless of whether the valve construction or mode of operation places it in the category of safety valve, relief valve, or safety relief valve.
 - (b) A self-actuated pressure valve that prevents operation of a fluid system at a higher-thandesired pressure by bleeding fluid from the system is a backpressure control valve [PCV], even if the valve is not intended to be used normally. However, this valve is designated a pressure

safety valve [PSV] if it protects against emergency conditions hazardous to personnel and/or equipment that are not expected to arise normally.

- (c) Pressure rupture disc [PSE] and fusible link [TSE] apply to all sensors or primary elements intended to protect against emergency pressure or temperature conditions.
- (d) [S] shall not be used to identify Safety Instrumented Systems and components, see (30).
- (15) The grammatical form of Succeeding Letter meanings shall be modified as required; for example, 'indicate' [I] may be read as 'indicator' or 'indicating,' and 'transmit' [T] may be read as 'transmitter' or 'transmitting.'
- (16) Readout/Passive Function glass, gauge, or viewing device [G] should be used instead of Readout/Passive Function indicate [I] for instruments or devices that provide a secondary view, such as level glasses, pressure gauges, thermometers, and flow sight glasses.
 - (a) Also used to identify devices that provide an uncalibrated view of plant operations, such as television monitors.
- (17) Readout/Passive Function indicate [I] applies to the analog or digital readout of an actual measurement or input signal to a discrete instrument or a distributed control system's video display unit.
 - (a) In the case of a manual loader, it should be used for the dial or setting indication of the output signal being generated, [HIC] or [HIK].
- (18) Readout/Passive Function scan [J] when used shall indicate a non-continuous periodic reading of two or more Measured/Initiating Variables of the same or different kinds, such as multipoint temperature and pressure recorders.
- (19) Readout/Passive Function light [L] identifies devices or functions that are intended to indicate normal operating status, such as motor on-off or actuator position, and is not intended for alarm indication.
- (20) Readout/Passive Function record [R] applies to any permanent or semi-permanent electronic or paper media storage of information or data in an easily retrievable form.
- (21) Readout/Passive and Output/Active Function multifunction [U] is used to:
 - (a) Identify control loops that have more than the usual indicate/record and control functions.
 - (b) Save space on drawings by not showing tangent bubbles for each function.
 - (c) A note describing the multiple functions should be on the drawing if needed for clarity.
- (22) Readout/Passive Function accessory [X] is intended to identify hardware and devices that do not measure or control but are required for the proper operation of instrumentation.
- (23) There are differences in meaning to be considered when selecting between Output/Active Functions for control [C], switch [S], valve, damper, or louver [V], and auxiliary device [Y]:
 - (a) Control [C] means an automatic device or function that receives an input signal generated by a Measured/Initiating Variable and generates a variable output signal that is used to modulate or switch a valve [V] or auxiliary device [Y] at a predetermined setpoint for ordinary process control.

- (b) Switch [S] means a device or function that connects, disconnects, or transfers one or more air, electronic, electric, or hydraulic signals, or circuits that may be manually actuated or automatically actuated directly by a Measured or Initiating Variable, or indirectly by a Measured or Initiating Variable transmitter.
- (c) Valve, damper, or louver [V] means a device that modulates, switches, or turns on/off a process fluid stream after receiving an output signal generated by a controller [C], switch [S], or auxiliary device [Y].
- (d) Auxiliary device [Y] means an automatic device or function actuated by a controller [C], transmitter [T], or switch [S] signal that connects, disconnects, transfers, computes, and/or converts air, electronic, electric, or hydraulic signals or circuits.
- (e) The succeeding letters CV shall not be used for anything other than a self-actuated control valve.
- (24) Output/Active Function control station [K] shall be used for:
 - (a) Designating an operator *accessible* control station used with an automatic controller that does not have an integral operator accessible auto-manual and/or control mode switch.
 - (b) Split architecture or fieldbus control devices where the controller functions are located remotely from the operator station.
- (25) Output/Active Function auxiliary devices and functions [Y] include, but are not limited to, solenoid valves, relays, and computing and converting devices and functions
- (26) Output/Active Function auxiliary devices [Y] for signal computing and converting when shown in a diagram or drawing shall be defined outside their bubbles with an appropriate symbol from Table 5.6 Mathematical Function Blocks and when written in text shall include a description of the mathematical function from Table 5.6.
- (27) Function Modifiers high [H], low [L], and middle or intermediate [M] when applied to positions of valves and other open-close devices, are defined as follows:
 - (a) High [H], the valve is in or approaching the fully open position, open [O] may be used as an alternative.
 - (b) Low [L] the valve is in or approaching the fully closed position; closed [C] may be used as an alternative.
 - (c) Middle or intermediate [M] the valve is traveling or located in between the fully open or closed position.
- (28) Function Modifier deviation [D] when combined with Readout/Passive Function [A] (alarm) or Output/Active Function S (switch) indicates a measured variable has deviated from a controller or other setpoint more than a predetermined amount.
 - (a) Function Modifiers high [H] or low [L] shall be added if only a positive or negative deviation, respectively, is of importance.
- (29) Function Modifiers high [H], low [L], and middle or intermediate [M] when applied to alarms correspond to values of the measured variable, not to values of the alarm-actuating signal, unless otherwise noted:

- (a) A high-level alarm derived from a reverse-acting level transmitter signal is an LAH, even though the alarm is actuated when the signal falls to a low value.
- (b) The terms shall be used in combination as appropriate to indicate multiple levels of actuation from the same measurement, for example high [H] and high-high [HH], low [L] and low-low [LL], or high-low [HL].
- (30) Variable Modifier [Z] is technically not a direct-measured variable but is used to identify the components of Safety Instrumented Systems.
 - (a) [Z] shall not be used to identify the safety devices noted in (14).

Table 4.1 — Identification letters

Note: Numbers in parentheses refer to the preceding explanatory notes in Clause 4.2. First letters (1) Succeeding letters (15) Column 1 Column 2 Column 3 Column 4 Column 5 Measured/Initiating Readout/Passive Variable Output/Active **Function** Variable Modifier (10) Function Modifier **Function** Analysis (2)(3)(4) Α Alarm Burner, Combustion (2) User's Choice (5) User's Choice (5) User's Choice (5) С User's Choice (3a)(5) Control (23a)(23e) Close (27b) Difference, Differential, D User's Choice (3a)(5) Deviation (28) (11a)(12a) Ε Voltage (2) Sensor, Primary Element Flow, Flow Rate (2) Ratio (12b) Glass, Gauge, Viewing G User's Choice Device (16) Hand (2) Н High (27a)(28a)(29) ı Current (2) Indicate (17) Power (2) Scan (18) Time Rate of Change Time, Schedule (2) Κ Control Station (24) (12c)(13)Low (27b)(28)(29) L Level (2) Light (19) Middle. Intermediate User's Choice (3a)(5) (27c)(28) (29) User's Choice (5) User's Choice (5) User's Choice (5) User's Choice (5) Ν Open (27a) 0 User's Choice (5) Orifice, Restriction Pressure (2) Ρ Point (Test Connection) Integrate, Totalize (11b) Q Quantity (2) Integrate, Totalize Radiation (2) Record (20) Run S Speed, Frequency (2) Safety(14) Switch (23b) Stop Т Temperature (2) Transmit U Multifunction (21) Multivariable (2)(6) Multifunction (21) Vibration, Mechanical Valve, Damper, Louver Analysis (2)(4)(7) (23c)(23e) Weight, Force (2) Well, Probe W Accessory Devices (22), Unclassified (8) Х Unclassified (8) X-axis (11c) Unclassified (8) Unclassified (8) **Auxiliary Devices** Υ Event, State, Presence (2)(9) Y-axis (11c) (23d)(25)(26) Driver, Actuator, Unclassified Z-axis (11c), Safety Position, Dimension (2) Instrumented System (30) final control element

5 Graphic symbol tables

- 5.1 Graphic symbol tables
- 5.1.1 This clause provides in tabular form the graphic building blocks that are used to construct diagrams for measurement and control loops, instruments, and functions in a concise, easily referenced manner.
- 5.1.2 The graphic symbol sets included in this clause are intended to be used to prepare:
 - a) Instrumentation diagrams.
 - b) Functional diagrams.
 - c) Binary logic diagrams.
 - d) Electrical schematics.
- 5.1.3 The graphic symbols shown in the tables are drawn full size for use in full size sketches or drawings.
- 5.1.4 The device and function symbols shown in Table 5.1.1 are based on the traditional 7/16-inch or 11mm circle format but may be changed to the often-used 1/2-inch or 12mm circle format.
- 5.1.5 Consideration shall be given to the size of reduced P&IDs when selecting symbol sizing.
- 5.1.6 All symbols shall maintain the size ratios shown in the tables when reduced or increased in size.
- 5.2 Tables to be used for common applications
- 5.2.1 Instrumentation diagrams that represent instrumentation devices and functions shall be constructed from the symbols shown in:
 - a) Tables 5.1.1 and 5.1.2 Measurement and control devices or functions.
 - b) Tables 5.2.1, 5.2.2, 5.2.3, and 5.2.4 Measurement elements and transmitters.
 - c) Tables 5.3.1 and 5.3.2 Lines, instrument to process or instrument to instrument.
 - d) Tables 5.4.1, 5.4.2, 5.4.3, and 5.4.4 Final control elements.
 - e) Table 5.6 Signal processing function blocks.
- 5.2.2 Functional diagrams that represent monitoring and control loops shall be constructed from the symbols shown in:
 - a) Table 5.5 Functional diagramming symbols.
 - b) Table 5.6 Signal processing function block symbols.
 - c) Table 5.7 Binary logic symbols.

- 5.2.3 Binary logic diagrams that represent logic processes shall be constructed from the symbols shown in:
 - a) Table 5.1.1 Measurement and control devices or functions.
 - b) Table 5.7 Binary logic symbols.
- 5.2.4 Electrical schematics that represent electrical circuits shall be constructed from the symbols shown in:
 - a) Table 5.1.1 Measurement and control devices or functions.
 - b) Table 5.8 Electrical schematic symbols.
- 5.2.5 Symbols may be developed to show devices and functions not covered by this standard or to simplify the depiction of frequently used instrumentation. Such uses shall be fully detailed by sketches or notes on the drawing legend and detail sheets.
- 5.2.6 If new or revised symbols are developed they should be submitted to the ISA-5.1 committee for inclusion in the next revision of this standard.
- 5.3 Graphic symbol table explanatory notes

The following notes, indicated in Tables 5.1 through 5.8 by parentheses, shall be used as an aid in understanding the meanings of the symbols.

- 5.3.1 Tables 5.1.1 and 5.1.2 Instrumentation device and function symbols:
- (1) Devices and functions that are represented by these bubble symbols are:
 - (a) Used in shared display, shared control, configurable, microprocessor-based, and datalinked instrumentation where the functions are accessible by the operator via a shared display or monitor.
 - (b) Configured in control systems that include, but are not limited to, distributed control systems (DCS), programmable logic controllers (PLC), personal computers (PC), and intelligent transmitters and valve positioners.
- (2) The user shall select and document one of the following for use of these symbols in a:
 - (a) Primary shared-display, shared-control system.
 - (b) Basic Process Control System (BPCS).
- (3) The user shall select and document one of the following for use of these symbols in an:
 - (a) Alternate shared-display, shared-control system.
 - (b) Safety Instrumented System (SIS).
- (4) Devices and functions represented by these bubble symbols are configured in computer systems that include, but are not limited to:

- (a) Process controllers, process optimizers, statistical process control, model-predictive process control, analyzer controllers, business computers, manufacturing execution systems, and other systems that interact with the process by manipulating setpoints in the BPCS.
- (b) High Level Control System (HLCS)
- (5) Discrete devices or functions that are hardware-based and are either stand-alone or are connected to other instruments, devices, or systems that include, but are not limited to, transmitters, switches, relays, controllers, and control valves.
- (6) Accessibility includes viewing, setpoint adjustment, operating mode changing, and any other operator actions required to operate the instrumentation.
- (7) Functions represented by these symbols are used for simple interlock logic:
 - (a) A description of the logic should be shown nearby or in the notes section of the drawing or sketch if the intended logic is not clearly understandable.
 - (b) These symbols are not recommended for depicting complex DCS, PLC, or SIS applications that require other than 'AND' and 'OR' signal gates.
- (8) A logic number, letter, or number/letter combination identification shall be used if more than one logic scheme is used on the project by:
 - (a) Replacing [I], [A], and [O] with the logic identification.
 - (b) Appending the logic identification outside the symbol.
- 5.3.2 Tables 5.2.1, 5.2.2, 5.2.3, 5.2.4, and 5.2.5 Measurement symbols
- (1) Measurements are depicted by:
 - (a) Bubbles only.
 - (b) Bubbles and graphics.
- (2) These symbols shall be used for process or equipment measurements if:
 - (a) A graphic symbol does not exist.
 - (b) The user does not use graphic symbols.
- (3) Transmitter [T] may be controller [C], indicator [I], recorder [R], or switch [S].
- (4) User engineering and design standards, practices, and/or guidelines shall document which choices are selected.
- 5.3.3 Tables 5.3.1 and 5.3.2 Line symbols:
- (1) Power supplies shall be shown when:
 - (a) Different from those normally used, e.g., 120 Vdc when normal is 24 Vdc.
 - (b) When a device requires an independent power supply.

- (c) Affected by controller or switch actions.
- (2) Arrows shall be used if needed to clarify direction of signal flow.
- (3) Users engineering and design standards, practices and/or guidelines shall document which symbol has been selected.
- (4) The line symbols connect devices and functions that are integral parts of dedicated systems, such as distributed control systems (DCS), programmable logic controllers (PLC), personal computer systems (PC), and computer control systems (CCS) over a dedicated communication link.
- (5) The line symbols connect independent microprocessor-based and computer-based systems to each other over a dedicated communications link, using but not limited to the RS232 protocol.
- (6) The line symbols connect "intelligent" devices, such as microprocessor-based transmitters and control valve positioners that contain control functionality, to other such devices and to the instrumentation system, using but not limited to Ethernet fieldbus protocols.
- (7) The line symbols connect "smart" devices, such as transmitters, to instrumentation system input signal terminals and provide a superimposed digital signal that is used for instrument diagnostics and calibration.
- 5.3.4 Tables 5.4.1, 5.4.2, 5.4.3 and 5.4.4 Final control element symbols:
- (1) Users engineering and design standards, practices, and/or guidelines shall document which symbols have been selected.
- (2) Element symbols 1 through 14, when combined with actuator symbols 1 through 16, represent process control valves.
- (3) Element symbol 2, when combined with actuator symbols 20 and 21, represent pressure safety valves.
- (4) Element symbols 15 through 19, when combined with actuator symbols 13, 14, and 15, represent on-off solenoid valves.
- (5) Element symbol 21, when combined with actuator symbols 1 through 16, represents a variable speed control unit.
- (6) Element symbol 21 represents a motor that manipulates or controls a process variable.
- (7) Actuator symbols 1 through 16, when combined with element symbols 1 through 14, represent process control valves and with element symbol 21 represents a variable speed control unit.
- (8) Actuator symbols 17, 18, and 19, when combined with element symbols 15 through 19, represent on-off solenoid valves.
- (9) Actuator symbols 20 and 21, when combined with element symbol 2, represent pressure safety valves.
- (10) The symbols are applicable to all types of control valves and actuators.
- 5.3.5 Table 5.5 Functional diagramming symbols:
- (1) Signal flow is assumed to be from top-to-bottom or from left-to-right.

- (2) Symbols are shown in a vertical diagram format.
- (3) Symbols shall be rotated 90 degrees counterclockwise in a horizontal diagram format.
- (4) Insert signal processing symbol from Table 5.6 at (*).
- 5.3.6 Table 5.6 Signal processing function block symbols:
- (1) Symbols in small squares and rectangles are as used with symbol #1 from Table 5.1.2.
- (2) Symbols in large rectangles are as used with symbol #5 from Table 5.5.
- (3) Users engineering and design standards, practices and/or guidelines shall document which symbol has been selected.
- 5.3.7 Table 5.7 Binary logic symbols:
- (1) True signals are equal to binary one, and false signals are equal to binary zero.
- (2) Alternate symbols shall be used only for "AND" and "OR" gates.
- (3) Users engineering and design standards, practices and/or guidelines shall document which symbol has been selected.
- 5.3.8 Table 5 8 Electrical schematic symbols
- (1) All devices are shown in the unactuated or de-energized condition.
- (2) Switch contacts 2, 3, and 4 shall be actuated by:
 - (a) Hand.
 - (b) Actuator symbols 5 and 6.
- (3) Actuator symbols 5 and 6 shall actuate switch symbols 2, 3, and 4.
- (4) Switch symbols 7, 8, and 9.shall be actuated by:
 - (a) Hand.
 - (b) Actuator symbols 11 through 16.
 - (c) Bubble symbol for device or function assigned to actuate the switch symbol.
- (5) Actuator symbols 11 through 16 shall actuate switch symbols 7, 8, and 9.
- (6) Users engineering and design standards, practices and/or guidelines shall document which symbol has been selected.

Table 5.1.1 — Instrumentation device and function symbols

Note: Numbers in parentheses refer to explanatory notes in Clause 5.3.1.

	Shared display, Shared control (1)		С			
	A B					
No.	Primary Choice or Basic Process Control System (2)	Alternate Choice or Safety Instrumented System (3)	Computer Systems and Software (4)	Discrete (5)	Location & accessibility (6)	
1					 Located in field. Not panel, cabinet, or console mounted. Visible at field location. Normally operator accessible. 	
2					 Located in or on front of central or main panel or console. Visible on front of panel or on video display. Normally operator accessible at panel front or console. 	
3			⟨ ⟩		 Located in rear of central or main panel. Located in cabinet behind panel. Not visible on front of panel or on video display. Not normally operator accessible at panel or console. 	
4					 Located in or on front of secondary or local panel or console. Visible on front of panel or on video display. Normally operator accessible at panel front or console. 	
5			===	===	 Located in rear of secondary or local panel. Located in field cabinet. Not visible on front of panel or on video display. Not normally operator accessible at panel or console. 	

Table 5.1.2 — Instrumentation device or function symbols, miscellaneous

No	Symbol	Description
1		 Signal processing function: Locate in upper right or left quadrant of symbols above. Attach to symbols above where affected signals are connected. Insert signal processing symbol from Table 5.6 Expand symbol by 50% increments for larger function symbols.
2	C 12	 Panel-mounted patchboard plug-in point. Console matrix point. C-12 equals patchboard column and row respectively, as an example.
3	(7) (8)	Generic interlock logic function. Undefined interlock logic function.
4	(7) (8)	'AND' interlock logic function.
5	(7) (8)	'OR' interlock logic function.
6		 Instruments or functions sharing a common housing. It is not mandatory to show a common housing. Notes shall be used to identify instruments in common housings not using this symbol.
7		 Pilot light. Circle shall be replaced with any symbol from column D in Table 5.1.1 if location and accessibility needs to be shown.

Table 5.2.1 — Measurement symbols: primary elements and transmitters

No	Symbol	Description
1	(1a) (2) ?E (*)	 Generic primary element, bubble format. Notation (*) from Table 5.2.2 should be used to identify type of element. Connect to process or other instruments by symbols from Tables 5.3.1 and 5.3.2. Insert in or on process flow line, vessel, or equipment.
2	(1a) ((2) (3) ?T (*)	 Transmitter with integral primary element, bubble format. Notation (*) from Table 5.2.2 should be used to identify type of element. Connect to process or other instruments by symbols from Tables 5.3.1 and 5.3.2. Insert in or on process flow line, vessel, or equipment.
3	(1a) (2) (3) ?T ?E (*)	 Transmitter with close coupled primary element, bubble format Notation (*) from Table 5.2.2 should be used to identify type of element. Connecting line shall be equal to or less than 0.25 inches (6 millimeters). Connect to process or other instruments by symbols from Tables 5.3.1 and 5.3.2. Insert element in or on process flow line, vessel, or equipment.
4	(1a) (3) ?T ?T (*)	 Transmitter with remote primary element, bubble format. Notation (*) from Table 5.2.2 should be used to identify type of element. Connecting line shall be equal to or greater than 0.5 inches (12 millimeters). Connect to process or other instruments by symbols from Tables 5.3.1 and 5.3.2. Insert element in or on process flow line, vessel, or equipment.
5	(1b) (3) ?T #	 Transmitter with integral primary element inserted in or on process flow line, vessel, or equipment, bubble/graphic format. Insert primary element symbol from Table 5.2.3 at #. Connect to other instruments by symbols from Table 5.3.2.
6	(1b) (3) ?T #	 Transmitter with close-coupled primary element inserted in or on process flow line, vessel, or equipment, bubble/graphic format. Insert primary element symbol from Table 5.2.3 at #. Connecting line shall be equal to or less than 0.25 inches (6 millimeters). Connect to other instruments by symbols from Table 5.3.2.
7	(1b) (3) ?E	 Transmitter with remote primary element inserted in or on process flow line, vessel, or equipment, bubble/graphic format. Insert primary element symbol from Table 5.2.3 at #. Connecting line may be any signal line from Table 5.2.3. Connecting line shall be equal to or greater than 0.5 inches (12 millimeters). Connect to other instruments by symbols from Table 5.3.2.

Table 5.2.2 — Measurement symbols: measurement notations (4)

Note: N	lur	nbers in parentheses r	eter to e	хр	lanatory notes in Clau						
						alysis					
AIR		Excess air	H2O		Water	02		= Oxygen	UV		 Ultraviolet
CO	=	Carbon monoxide	H2S		Hydrogen sulfide	OP		= Opacity	VIS		Visible light
CO2		Carbon dioxide	HUM	=	Humidity	ORP	:	 Oxidation reduction 	VISC		= Viscosity
COL		Color	IR	=	Infrared	pН	:	 Hydrogen ion 			=
COMB		Combustibles	LC	=	Liquid chromatograph	REF	:	= Refractometer			=
COND	=	Elec. conductivity	MOIST	=	Moisture	RI	:	 Refractive index 			=
DEN	=	Density	MS	=	Mass spectrometer	TC	:	 Thermal conductivity 			=
GC	=	Gas chromatograph	NIR	=	Near infrared	TDL	:	Tunable diode laser			=
					F	low					
CFR	=	Constant flow regulator	OP	=	Orifice plate	PT	:	= Pitot tube	VENT		= Venturi tube
CONE	=	Cone	OP-CT	=	Corner taps	PV	:	= Pitot venturi	VOR		 Vortex Shedding
COR	=	Coriollis	OP-CQ		Circle guadrant	SNR	:	= Sonar	WDG		= Wedge
DOP	=	Doppler	OP-E		Eccentric	SON		Sonic			=
DSON		Doppler sonic	OP-FT		Flange taps	TAR	:	= Target			
FLN		Flow nozzle			Multi-hole	THER		= Thermal			=
FLT		Flow tube	OP-P		Pipe taps	TTS		= Transit time sonic			=
LAM		Laminar	OP-VC		Vena contracta taps	TUR		= Turbine			=
MAG		Magnetic	PD		Positive displacement	US		= Ultrasonic			=
IVIAO		Wagnetie	יו	_		evel		- Ottasonic			
CAP	_	Capacitance	GWR	_	Guided wave radar	NUC		- Nuclear	US		= Ultrasonic
d/p		Differential pressure	LSR		Laser	RAD		Radar	00		= 01(18501110
DI		Dielectric constant	MAG		Magnetic	RES		Resistance			=
DP		Differential pressure	MS		Magnetostrictive	SON		Sonic			- =
וט	÷	Dilicientiai pressure	IVIO	-	0	ssure	_	- Soriic		_	
ABS	_	Absolute	MAN	_	Manometer	VAC	-	= Vacuum			
AVG		Average	P-V		Pressure-vacuum	VAC	•	- vacuum			=
DRF		Draft	SG					=			- =
DKF	-	Diail	36	_	Strain gage	oroturo	_	-		_	_
BM	_	Bi-metallic	RTD	_	Resistance temp detector	erature TCK	_	Thermoseunie time I/	TRAN	-	= Transistor
IR		Infrared	TC		Thermocouple	TCT		Thermocouple type K Thermocouple type T	IKAN		- Transistor =
RAD			TCE			THRM		. ,,			- =
RP		Radiation			Thermocouple type E	TMP		Thermistor			- =
RP	_	Radiation pyrometer	TCJ	_	Thermocouple type J			= Thermopile		_	=
-		mar Cambustian	1		NIISCE	llaneous	<u> </u>	Ougntitu	1		Dadiation
		ner, Combustion	CAR	_	Position	PE	_	Quantity	l	-	Radiation
FR		Flame rod	CAP		Capacitance			Photoelectric	α		Alpha radiation
IGN	=	Igniter	EC		Eddy current	TOG	=	- 55	β	=	
IR TV	=	Infrared	IND		Inductive		=		γ	=	Janna radiation
TV		Television	LAS		Laser		=		n	=	
UV	=	Ultraviolet	MAG		Magnetic		=			=	
	=		MECH		Mechanical		=			=	
	=		OPT		Optical		=			=	
	=		RAD		Radar		=			=	
	=			=			Ξ			Ξ	
		Speed			Weight, Force				ļ		
ACC	=		LC		Load cell			=			=
EC	=	,	SG		Strain gauge		:	=			=
PROX	=	,	WS	=	Weigh scale			=			=
VEL	=	Velocity		=			:	=			=
	=			=			:	=			=

Table 5.2.3 — Measurement symbols: primary elements

Note	No	S in parentheses refer to explain Symbol (4)	Description
Analysis	1	•	 Conductivity, moisture, etc. Single element sensing probe.
Analysis	2	• 1	pH, ORP, etc.Dual element sensing probe.
Analysis	3	2	Fiberoptic sensing probe.
Burner	4	2	 Ultraviolet flame detector. Television flame monitor.
Burner	5		Flame rod flame detector.
Flow	6		Generic orifice plate. Restriction orifice.
Flow	7		Orifice plate in quick-change fitting.
Flow	8		Concentric circle orifice plate. Restriction orifice.
Flow	9		Eccentric circle orifice plate.
Flow	10		Circle quadrant orifice plate.
Flow	11	<u></u>	Multi-hole orifice plate
Flow	12	(*)	 Generic venturi tube, flow nozzle, or flow tube. Notation from Table 5.2.2 required at (*) if used for more than one type.
Flow	13	M	Venturi tube.
Flow	14		Flow nozzle.
Flow	15		Flow tube.

Table 5.2.3 — Measurement symbols: primary elements

14016	No	s in parentheses refer to expla Symbol (4)	Description
Flow	16		Integral orifice plate.
Flow	17		Standard pitot tube.
Flow	18		Averaging pitot tube.
Flow	19	[8]	Turbine flowmeter.Propeller flowmeter.
Flow	20		Vortex shedding flowmeter
Flow	21	F	Target flowmeter.
Flow	22	(4) a) M b) (M)	Magnetic flowmeter.
Flow	23	(4) a) ΔT b) :	Thermal mass flowmeter.
Flow	24	8	Positive displacement flowmeter.
Flow	25		Cone meter.Annular orifice meter.
Flow	26	igwedge	Wedge meter.
Flow	27		Coriollis flowmeter.
Flow	28	[2]	Sonic flowmeter.Ultrasonic flowmeter.
Flow	29	D	Variable area flowmeter.
Flow	30		Open channel weir plate.

Table 5.2.3 — Measurement symbols: primary elements

	No	Symbol (4)	Description
Flow	31		Open channel flume.
Level	32		Displacer internally mounted in vessel.
Level	33		Ball float internally mounted in vessel. May be installed through top of vessel.
Level	34	2	Radiation, single point.Sonic.
Level	35	3	Radiation, multi-point or continuous.
Level	36		 Dip tube or other primary element and stilling well. May be installed through side of vessel. May be installed without stilling well.
Level	37		 Float with guide wires. Location of readout should be noted, at grade, at top, or accessible from a ladder. Guide wires may be omitted.
Level	38		Insert probe. May be through top of vessel.
Level	39	<u> </u>	Radar.
Pressure	40	PE (*)	 Strain gage or other electronic type sensor. Notation (*) from Table 5.2.2 should be used to identify type of element. Connection symbols 6, 7, 8, or 9 in Table 5.3.1 are used if connection type is to be shown. Bubble may be omitted if connected to another instrument.

Table 5.2.3 — Measurement symbols: primary elements

Note: Numbers in parentheses refer to explanatory notes in Clause 5.3.2.

	No	Symbol (4)	Description
Temperature	41	TE (*)	 Generic element without thermowell. Notation (*) should be used to identify type of element, see Table 5.2.2. Connection symbols 6, 7, 8, or 9 in Table 5.3.1 are used if connection type is to be shown. Bubble may be omitted if connected to another instrument.

Table 5.2.4 — Measurement symbols: secondary instruments

	No	Symbol (4)	Description
Flow	1	FG	Sight glass.
Level	2	LG	 Gage integrally mounted on vessel. Sight glass.
Level	3	LG	 Gage glass externally mounted on vessel or standpipe. Multiple gages may be shown as one bubble or one bubble for each section. Use connection 6, 7, 8, or 9 in Table 5.3.1 if connection type is to be shown.
Pressure	4	PG	 Pressure gage. Use connection 6, 7, 8, or 9 in Table 5.3.1 if connection type is to be shown.
Temperature	5	TG	 Thermometer. Use connection 6, 7, 8, or 9 in Table 5.3.1 if connection type is to be shown.

Table 5.2.5 — Measurement symbols: auxiliary and accessory devices

	No	Symbol (4)	Description
Analysis	1	T	 Sample insert probe, flanged. Sample well, flanged. Use connection 7, 8, or 9 in Table 5.3.1 if flange is not used.
Analysis	2	AX	 Sample conditioner or other analysis accessory, flanged. Represents single or multiple devices. Use connection 7, 8, or 9 in Table 5.3.1 if flange is not used.
Flow	3	FX	 Flow straightening vanes. Flow conditioning element.
Flow	4	P	 Instrument purge or flushing fluid. Instrument purge or flushing device or devices. Show assembly details on drawing legend sheet.
Pressure	5	-{}-	 Diaphragm pressure seal, flanged, threaded, socket welded, or welded. Diaphragm chemical seal, flanged, threaded, socket welded, or welded. Use connection 6, 7, 8, or 9 in Table 5.3.1 if connection type is to be shown.
Pressure	6		 Diaphragm pressure seal, welded. Diaphragm chemical seal, welded.
Temperature	7	TW	 Thermowell, flanged. Test well, flanged. Bubble may be omitted if connected to another instrument. Use connection 7, 8, or 9 in Table 5.3.1 if flange is not used.

Table 5.3.1 — Line symbols: instrument to process and equipment connections

No	Symbol	Application
1		 Instrument connections to process and equipment. Process impulse lines. Analyzer sample lines.
2	(ST)	 Heat [cool] traced impulse or sample line from process. Type of tracing indicated by: [ET] electrical, [ST] steam, [CW] chilled water, etc.
3		 Generic instrument connection to process line. Generic instrument connection to equipment.
4	!	 Heat [cool] traced generic instrument impulse line. Process line or equipment may or may not be traced.
5		Heat [cool] traced instrument. Instrument impulse line may or may not be traced.
6	т	 Flanged instrument connection to process line. Flanged instrument connection to equipment.
7		 Threaded instrument connection to process line. Threaded instrument connection to equipment.
8		 Socket welded instrument connection to process line. Socket welded instrument connection to equipment.
9		 Welded instrument connection to process line. Welded instrument connection to equipment.

Table 5.3.2 — Line symbols: instrument-to-instrument connections

No	Symbol	explanatory notes in Clause 5.3.3. Application
1	(1) IA ———	 IA may be replaced by PA [plant air], NS [nitrogen], or GS [any gas supply]. Indicate supply pressure as required, e.g., PA-70 kPa, NS-150 psig, etc.
2	(1) ES ———	 Instrument electric power supply. Indicate voltage and type as required, e.g. ES-220 Vac. ES may be replaced by 24 Vdc, 120 Vac, etc.
3	(1) HS ————	 Instrument hydraulic power supply. Indicate pressure as required, e.g., HS-70 psig.
4	(2)	 Undefined signal. Use for Process Flow Diagrams. Use for discussions or diagrams where type of signal is not of concern.
5	(2)	Pneumatic signal, continuously variable or binary.
6	(2)	 Electronic or electrical continuously variable or binary signal. Functional diagram binary signal.
7	(2)	 Functional diagram continuously variable signal. Electrical schematic ladder diagram signal and power rails.
8	(2)	Hydraulic signal.
9	(2)	 Filled thermal element capillary tube. Filled sensing line between pressure seal and instrument.
10	(2)	 Guided electromagnetic signal. Guided sonic signal. Fiber optic cable.
11	(3) a) \(\sum_{b} \)	 Unguided electromagnetic signals, light, radiation, radio, sound, wireless, etc. Wireless instrumentation signal. Wireless communication link.
12	(4)o	 Communication link and system bus, between devices and functions of a shared display, shared control system. DCS, PLC, or PC communication link and system bus.
13	(5)	 Communication link or bus connecting two or more independent microprocessor or computer-based systems. DCS-to-DCS, DCS-to-PLC, PLC-to-PC, DCS-to-Fieldbus, etc. connections.
14	(6)	 Communication link and system bus, between devices and functions of a fieldbus system. Link from and to "intelligent" devices.
15	(7)	 Communication link between a device and a remote calibration adjustment device or system. Link from and to "smart" devices.

Table 5.3.2 — Line symbols: instrument-to-instrument connections

No	Symbol	Application
16	- ●•	Mechanical link or connection.
17	(3) a) (#) (##) b) (#) (##) b) (#) (##) (#) (##)	 Drawing-to-drawing signal connector, signal flow from left to right. (#) = Instrument tag number sending or receiving signal. (##) = Drawing or sheet number receiving or sending signal.
18	(*)	 Signal input to logic diagram. (*) = Input description, source, or instrument tag number.
19	(*)	 Signal output from logic diagram. (*) = Output description, destination, or instrument tag number.
20	(*)	 Internal functional, logic, or ladder diagram signal connector. Signal source to one or more signal receivers. (*) = Connection identifier A, B, C, etc.
21	(*)	 Internal functional, logic, or ladder diagram signal connector. Signal receiver, one or more from a single source. (*) = Connection identifier A, B, C, etc.

Table 5.4.1 — Final control element symbols

No	Symbol	explanatory notes in Clause 5.3.4. Description		
1	(1) (2) a) b)	 Generic two-way valve. Straight globe valve. Gate valve. 		
2	(2) (3)	 Generic two-way angle valve. Angle globe valve. Safety angle valve. 		
3	(2)	 Generic three-way valve. Three-way globe valve. Arrow indicates failure or unactuated flow path. 		
4	(2)	 Generic four-way valve. Four-way four-ported plug or ball valve. Arrows indicates failure or unactuated flow paths. 		
5	(2)	Butterfly valve.		
6	(2)	Ball valve.		
7	(2)	Plug valve		
8	(2)	Eccentric rotary disc valve.		
9	(1) (2) a) b)	Diaphragm valve.		
10	(2)	Pinch valve.		
11	(2)	Bellows sealed valve.		
12	(2)	Generic damper. Generic louver.		
13	(2)	 Parallel blade damper. Parallel blade louver. 		
14	(2)	 Opposed blade damper. Opposed blade louver. 		

Table 5.4.1 — Final control element symbols

No	Symbol	Description	
15	(4)	Two-way on-off solenoid valve.	
16	(4)	Angle on-off solenoid valve.	
17	(4)	 Three-way on-off solenoid valve. Arrow indicates de-energized flow path. 	
18	(4)	 Four-way plug or ball on-off solenoid valve. Arrows indicates de-energized flow paths. 	
19	(4)	Four-way five-ported on-off solenoid valve. Arrows indicates de-energized flow paths.	
20	(5)	Permanent magnet variable speed coupling.	
21	(6)	Electric motor.	

Table 5.4.2 — Final control element actuator symbols

No	Symbol	Description	
1	(7)	 Generic actuator. Spring-diaphragm actuator. 	
2	(7)	Spring-diaphragm actuator with positioner.	
3	(7)	Pressure-balanced diaphragm actuator.	
4	(7)	 Linear piston actuator. Single acting spring opposed Double acting. 	
5	(7)	Linear piston actuator with positioner.	
6	(7)	 Rotary piston actuator. May be single acting spring opposed or double acting. 	
7	(7)	Rotary piston actuator with positioner.	
8	(7)	Bellows spring opposed actuator.	
9	(7)	 Rotary motor operated actuator. Electric, pneumatic, or hydraulic. Linear or rotary action. 	
10	(7) S	 Modulating solenoid actuator. Solenoid actuator for process on-off valve. 	
11	(7) 	Actuator with side-mounted handwheel.	
_			

Table 5.4.2 — Final control element actuator symbols

No	Symbol	Description		
12	(7)	Actuator with top-mounted handwheel.		
13	(7)	Manual actuator. Hand actuator.		
14	(7) EH	Electrohydraulic linear or rotary actuator.		
15	(7)	Actuator with manual actuated partial stroke test device.		
16	(7)	Actuator with remote actuated partial stroke test device.		
17	(8) S	 Automatic reset on-off solenoid actuator. Non-latching on-off solenoid actuator. 		
18	(8)	 Manual or remote reset on-off solenoid actuator. Latching on-off solenoid actuator. 		
19	(8)	 Manual and remote reset on-off solenoid actuator. Latching on-off solenoid actuator. 		
20	(9)	Spring or weight actuated relief or safety valve actuator.		
21	(9)	 Pilot actuated relief or safety valve actuator. Pilot pressure sensing line deleted if sensing is internal. 		

Table 5.4.3 — Self-actuated final control element symbol

No	Symbol	Description		
1	→ (XXX)	 Automatic flow regulator. XXX = FCV without indicator. XXX = FICV with integral indicator. 		
2	(1) (2) (a) FICV	 Variable area flowmeter with integral manual adjusting valve. Instrument tag bubble required with (b). 		
3	FICV	Constant flow regulator.		
4	FG	 Flow sight glass. Type shall be noted if more than one type used. 		
5	FO	 Generic flow restriction. Single stage orifice plate as shown. Note required for multi-stage or capillary tube types. 		
6	FO	 Restriction orifice hole drilled in valve plug. Tag number shall be omitted if valve is otherwise identified. 		
7	TANK	Level regulator. Ball float and mechanical linkage.		
8		Backpressure regulator. Internal pressure tap.		
9		Backpressure regulator. External pressure tap.		

Table 5.4.3 — Self-actuated final control element symbol

No	Symbol	Description		
10	→	Pressure-reducing regulator. Internal pressure tap.		
11	—	 Pressure-reducing regulator. External pressure tap. 		
12		 Differential pressure regulator. External pressure taps. 		
13		 Differential pressure regulator. Internal pressure taps. 		
14	PG	Pressure-reducing regulator w/ integral outlet pressure relief and pressure gauge.		
15	<u></u>	 Generic pressure safety valve. Pressure relief valve. 		
16	→	Generic vacuum safety valve. Vacuum relief valve.		
17	→	Generic pressure - vacuum relief valve. Tank pressure - vacuum relief valve.		
18		 Pressure safety element. Pressure rupture disk. Pressure relief. 		
19		 Pressure safety element. Vacuum rupture disk. Vacuum relief. 		

Table 5.4.3 — Self-actuated final control element symbol

No	Symbol	Description
20		 Temperature regulator. Filled thermal system.
21	TANK	 Thermal safety element. Fusible plug or disk.
22		 Generic moisture trap. Steam trap. Note required for other trap types.
23	TANK	Moisture trap with equalizing line.

Table 5.4.4 — Control valve failure and de-energized position indications

No	Method A (1) (10)	Method B (1) (10)	Definition
1			Fail to open position.
2	FC		Fail to closed position.
3	☐ X _{FL}		Fail locked in last position.
4	FL/DO		Fail at last position.Drift open.
5	FL/DC		Fail at last position.Drift closed.

Table 5.5 — Functional diagramming symbols

No	Symbol (1) (2)	Description		
1	[*]	 Measuring, input, or readout device. [*] = Instrument tag number. Symbols from Table 5.2.1 may be used. 		
2	(3) (4)	Automatic single-mode controller.		
3	(3) (4) (*) (*)	Automatic two-mode controller.		
4	(3) (4) (*) (*) (*) (*)	Automatic three-mode controller.		
5	(3) (4)	Automatic signal processor.		
6	(4)	Manual signal processor.		
7	(3) (4)	Final control element. Control valve.		
8	(3) (4)	 Final control element with positioner. Control valve with positioner. 		

Table 5.6 — Signal processing function block symbols

	e: Numbers in parentheses refer to explanatory notes in Clause 5.3.6. Function Equation No		Definition	
NO	Symbol (1) (2)	Graph	Definition	
1	Summation	$M = X_1 + X_2 + X_n$	Output equals algebraic sum of inputs.	
	Σ	x M		
	Σ	X ₁ X ₂ X ₁ t		
2	Average	$M = X_1 + X_2 + X_n/n$	Output equals algebraic sum of inputs divided by number of inputs.	
	Σ/n Σ/n	X X_1 X_2 X_3 X_4 X_5 X_4 X_5		
3	Difference	$M = X_1 - X_2$	Output equals algebraic difference of two inputs.	
	Δ	X X_1 X_2 X_2 X_3 X_4 X_4 X_5		
4	Multiplication	$M = X_1 \times X_2$	Output equals product of two inputs.	
	X	X X_1 X_2 X_2 X_1 X_2 X_1 X_2 X_1 X_2 X_3 X_4 X_4 X_4 X_5 X_5 X_1 X_2 X_3 X_4 X_5		

Table 5.6 — Signal processing function block symbols

No	Function	r to explanatory notes in Clause 5.3.6. Equation		Definition
NO	Symbol (1) (2)	Graph		Definition
5	Division	$M = X_1 \div X_2$	•	Output equals quotient of two inputs.
	÷	X X ₁ M		
	÷	X_2 t_1 t		
6	Exponential	M = X ⁿ	•	Output equals nth power of input.
	X ⁿ	x M		
	X ⁿ	t		
7	Root extraction	M = ⁿ √X	-	Output equals nth root of input. If 'n' omitted, square root is assumed.
	¹√	x M		
	n.	t		
8	Proportion	M = KX or M = PX	•	Output proportional to input. Replace 'K' or 'P' with '1:1' for
	(3) a) K b) P	x M	•	volume boosters. Replace 'K' or 'P' with '2:1', '3:1', etc., for integer gains.
	(3) K b) P	t ₁ t ₁ t		

Table 5.6 — Signal processing function block symbols

Note: Numbers in parentheses refer to explanatory notes in Clause 5.3.6. Function **Equation** Definition No Symbol (1) (2) Graph Output inversely proportional to M = -KX or M = -PXReverse proportion 9 Replace '-K' or '-P' with '-1:1' for (3) volume boosters. a) -K b) -P Replace '-K' or '-P' with '-2:1', Χ '-3:1', etc., for integer gains. (3)-K -P Output varies with magnitude and Integral $M = (1/T_1)\mathbf{I}Xdt$ time duration of input. 10 Output proportional integral of input. (3) b) | I T_1 = Integral time constant. Μ (3) a) b) Output proportional to time rate of Derivative $M = T_D (dx/dt)$ change of input. 11 T_D = derivative time constant. (3) a) d/dt (3) a) d/dt D b) Output is a nonlinear Unspecified function M = f(x)unspecified function of the input. 12 Function defined in note or other $f_{(\mathsf{x})}$ $f_{(x)}$

Table 5.6 — Signal processing function block symbols

	Function	r to explanatory notes in Clause 5.3.6. Equation	Definition
No	Symbol (1) (2)	Graph	Definition
13	Time function $f_{(t)}$	M = Xf(t) X	Output equals a nonlinear or unspecified time function times the input. Output is a nonlinear or unspecified time function. Function defined in note or other text.
14	Conversion	I = P, P = I, etc	Output signal type different from that of input signal.
14	I/P	X M t	 Input signal is on the left and output signal is on the right. Substitute any of the following signal types for 'P' or 'I': A = Analog H = Hydraulic B = Binary I = Current D = Digital O = Electromagnetic E = Voltage P = Pneumatic F = Frequency R = Resistance
15	High signal select	$M = X_1 \text{ for } X_1 > X_2$ $M = X_2 \text{ for } X_1 \le X_2$	Output equals greater of 2 or more inputs.
	>	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	
16	Middle signal select	$ M = X_1 \text{ for } X_2 > X_1 > X_3 \text{ or } X_3 > X_1 > X_2 $ $ M = X_2 \text{ for } X_1 > X_2 > X_3 \text{ or } X_3 > X_2 > X_1 $ $ M = X_3 \text{ for } X_1 > X_3 > X_2 \text{ or } X_2 > X_3 > X_1 $	Output equals middle value of three or more inputs.
	M	X X_2 X_1 X_3 X_3 X_4 X_4 X_4 X_5	

Table 5.6 — Signal processing function block symbols

	Function	r to explanatory notes in Clause 5.3.6. Equation		Definition
No	Symbol (1) (2)	Graph		Definition
17	Low signal select	$M = X_1 \text{ for } X_1 \le X_2$ $M = X_2 \text{ for } X_1 \ge X_2$	•	Output equals lesser of 2 or more inputs.
		X		
	<	$\frac{X_2}{t_1}$ $\frac{1}{t_1}$ $\frac{1}{t_1}$		
18	High limit	$M = X \text{ for } X \le H$ $M = H \text{ for } X \ge H$	•	Output equals the lower of the input or high limit values.
	≯	X M		
	>	t ₁ t		
19	Low limit	$M = X \text{ for } X \ge L$ $M = L \text{ for } X \le L$	•	Output equals the higher of the input or low limit values.
		X M		
		t_1 t t_1 t		
20	Positive bias	$M = X_1 + b$ $M = [-]X_2 + b$	•	Output equal to input plus an arbitrary value.
	+	X X ₂ X ₁ / M		
	+	t ₁ t ₂ t t ₁ t ₂ t		

Table 5.6 — Signal processing function block symbols

Note. Nul	Function	r to explanatory notes in Clause 5.3.6. Equation		
No	Symbol (1) (2)	- Graph		Definition
21	Negative Bias	$M = X_1 - b$ $M = [-]X_2 - b$	•	Output equal to input minus an arbitrary value.
		X X ₂ X ₁ M		
		t ₁ t ₂ t t ₁ t ₂ t		
22	Velocity limiter	$dM/dt = dX/dt$ for $dX/dt \le H$, $M = X$ $dM/dt = H$ for $dX/dt \ge H$, $M \ne X$	•	Output equals input as long as the input rate of change does not
	(3) a) ₩ b) V≯	X dX/dt>H dM/dt=H		exceed the limit value that establishes the output rate of change until the output again equals the input.
	(3) a) ∨ b) ∨ >	t ₁ t _{2,3} t t ₁ t ₂ t ₃ t		
23	High signal monitor	(State 1) M = 0 @ X < H (State 2) M = 1 @ X ≥ H	-	Output state is dependent on value of input. Output changes state when input is equal to or higher than an
	Н	X M State		arbitrary high limit.
	Н	State State t ₁ t t ₁ t		
24	Low signal monitor	(State 1) M = 1 @ X ≤ L (State 2) M = 0 @ X > L	-	Output state is dependent on value of input. Output changes state when input
	L	X M State State		is equal to or lower than an arbitrary low limit.
	L	State State State t t t t		

Table 5.6 — Signal processing function block symbols

No	Function	r to explanatory notes in Clause 5.3.6. Equation	Definition
NO	Symbol (1) (2)	Graph	Deminion
25	High/low signal monitor	(State 1) M = 1 @ X ≤ L (State 2) M = 0 @ L < X < H (State 3) M = 1 @ X ≥ H	Output states are dependent on value of input. Output changes state when input is equal to or lower than an
	HL	X M State State State State	arbitrary low limit or equal to or higher than an arbitrary high limit.
26	Analog signal generator	No equation	Output equals a variable analog signal that is generated:
	A	No graph	a.Automatically and is not adjustable by operator. b. Manually and is adjustable by operator.
27	Binary signal generator	No equation	Output equals an on-off binary signal that is generated:
2,	В	No graph	aAutomatically and is not adjustable by operator. b. Manually and is adjustable by operator.
28	Signal transfer	(State 1) M = X ₁ (State 2) M = X ₂	Output equals input that is selected by transfer.
	Т	X X ₁ M State State X Analog signal transfer X X ₁ M State State	Transfer actuated by external signal.
		t ₁ t t ₁ t Binary signal transfer	

Table 5.7 — Binary logic symbols


	Function	Definition (1)	
No	Symbol		
	Truth Table (1)	Graph	
1	AND gate	Output true only if all inputs are true. Alternate symbol. (2) (3)	
	A> B> A C> N X> O	$ \begin{array}{c} A > \\ B > \\ C - \tau > A \end{array} $ $ \begin{array}{c} A > 0 \\ X - \frac{1}{2} > 0 $	
	A B C X O 1 0 0 0 0 0 0 0 0 0	A B C X O 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16	
2	OR gate	Output true if any input is true. Alternate symbol. (2) (3)	
	$ \begin{array}{c} A > \\ B > \\ C - + > \\ X - + > \end{array} $ OR -> 0	A> B> C> O X> O	
	A B C X O 1 0 0 0 0 0 0 0 0 0	A B C X O 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16	

	Function	fer to explanatory notes in Clause 5.3.7. Definition (1)	
No	Symbol		
	Truth Table (1)	Graph	
	NAND gate	 Output true only if all inputs are false. Output false if any input is true. 	
3	A> N B> A C - +> N X - +> D	Output faise if any input is true.	
	A B C X O 1 0 0 0 0 1 2 1 0 0 0 0 0 0 3 0 1 0 0 0 0 0 0 0 0	A B C X O I I I I I I I I I I I I I I I I I I	
4	NOR gate A> B> C> X>	 Output true if any input is false. Output false if any input is true. 	
	A B C X O 1 0 0 0 0 1 2 1 0 0 0 0 1 3 0 1 0 0 1 4 0 0 1 0 1 5 0 0 0 1 1 6 1 1 0 0 1 7 1 0 1 0 1 8 1 0 0 1 1 9 0 1 1 0 1 11 0 0 1 1 11 0 0 1 1 12 1 1 0 1 13 1 0 1 1 14 1 0 1 1 15 0 1 1 1 16 1 1 1 0	A B C X O 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16	

Note: Numbers in parentheses refer to explanatory notes in Clause 5.3.7. Function Definition (1)		
No	Symbol	
	Truth Table (1)	Graph
5	Qualified OR gate Greater or equal to 'n'	 Output true if number of true inputs is greater than or equal to 'n'. Truth table and graph are for n = 2.
	A> B> C> X> 0	
	A B C X O 1 0 0 0 0 0 0 0 0 0	A B C X O 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16
6	Qualified OR gate Greater than 'n'	 Output true if number of true inputs is greater than 'n'. Truth table and graph are for n = 2.
	B> C> X>	
	A B C X O 1 0 0 0 0 0 0 0 0 0	A B C X O 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16

Note: Nu	Function Definition (1)	
No	Symbol	
	Truth Table (1)	Graph
7	Qualified OR gate Less or equal to 'n'	 Output true if number of true inputs is less than or equal to 'n'. Truth table and graph are for n = 2.
	$ \begin{vmatrix} A > \\ B > \\ C - + > \\ X - + > \end{vmatrix} \le n > 0 $	
	A B C X O 1 0 0 0 0 1 2 1 0 0 0 0 1 3 0 1 0 0 1 0 1 0 1 0 0	A B C X O 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16
8	Qualified OR gate Less than 'n'	Output true if number of true inputs is less than 'n'. Truth table and graph are for n = 2.
	A> B> C> X>	
	A B C X O	A B C X O 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16

Note: Nui		er to explanatory notes in Clause 5.3.7.
	Function	Definition (1)
No	Symbol	
	Truth Table (1)	Graph
	Qualified OR gate	Output true if number of true inputs is equal to 'n'.
9	Equal to 'n'	Truth table and graph are for n = 2.
	A> B>	
	C - T > 0	
	X - 1 >	
	A B C X O 1 0 0 0 0 0	
	2 1 0 0 0 0 3 0 1 0 0 0	
	4 0 0 1 0 0	
	6 1 1 0 0 1	
	7 1 0 1 0 1 8 1 0 0 1 1	
	9 0 1 1 0 1	│× ├┼─┼─┼─┦ ─ ┞─┼ ─┦┞─┦╎┞─┦╎╎┡─
	11 0 0 1 1 1 12 1 1 1 0 0	
	13 1 1 0 1 0 14 1 0 1 1 0	
	15 0 1 1 1 0	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16
	Qualified OR gate Not equal to 'n'	 Output true if number of true inputs is not equal to 'n'. Truth table and graph are for n = 2.
10		
	A — → I	
	B> C - +> (≠n)> 0	
	X - +>	
	^/	
	A B C X O	
	1 0 0 0 0 1 2 1 0 0 0 1	
	3 0 1 0 0 1 4 0 0 1 0 1	
	5 0 0 0 1 1 6 1 1 0 0 0	│ _₿ ├ ┆ ┆┛╸┆┚╸┪╸┆
	7 1 0 1 0 0	
	9 0 1 1 0 0	
	10 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 1	^ <u> </u>
	12 1 1 1 0 1 13 1 1 0 1 1	▎○┝┩┆┆┆ ┞┆┆┞
	14 1 0 1 1 1 1 1 1 1 1	1 2 2 4 5 6 7 9 0 40 41 42 42 44 45 46
		1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16
	1 1 1 1 1 1 1 1	



Note: Nu	mbers in parentheses refe	er to explanatory notes in Clause 5.3.7.	
NI-	Function	Definition (1)	
No	Symbol		
	Truth Table (1)	Graph	
14	Reset dominant memory $A \longrightarrow S \longrightarrow C$ $B \longrightarrow RO \longrightarrow D$	 Outputs [C] and [D] are always opposite. If input [A] equals (1) then output [C] equals (1) and output [D] equals (0). If input [A] changes to (0) output [C] remains (1) until input [B] equals (1) then output [C] equals (1) and output [D] equals (0). If input [B] equals (1) then output [D] equals (1) and output [C] equals (0). If input [B] changes to (0) output [D] remains (1) until input [A] equals (1), then output [D] equals (1) and output [C] equals (0). If inputs [A] and [B] are simultaneously equal to (1) then output [C] equals (0) and output [D] equals (1). 	
	A B C D 1 0 0 0 1 2 1 0 1 0 3 0 0 1 0 4 0 1 0 1 5 0 0 0 1 6 1 1 0 1 7 0 0 0 1 8 1 1 0 1	A B C D 1 2 3 4 5 6 7 8 t	
	Pulse duration - fixed	• Output [O] changes from (0) to (1) and remains (1) for prescribed time duration (t) when input [I] changes from (0) to (1).	
15	$ -\Rightarrow \boxed{t PD -\Rightarrow 0}$		
	NONE		
	Time delay - off	 Output [O] changes from (0) to (1) when input [I] changes from (0) to (1). Output [O] changes from (1) to (0) after input [I] changes from (1) to (0) and has been 	
16	$t \to DT \to 0$	equal to (0) for time duration ('t).	
	NONE		

	Function	Definition (1)	
No	Symbol		
	Truth Table (1)	Graph	
	Time delay - on	Output [O] changes from (0) to (1) after input [I] changes from (0) to (1) and [I] remains (1) for prescribed time duration (t).	
17	$\begin{vmatrix} 1 - \Rightarrow & t & GT \\ R - \tilde{x}^T & & & \end{vmatrix}$	Output [O] remains (1) until Input [I] changes to (0) or optional Reset [R] changes to (1).	
	NONE		
18	Pulse duration - variable $ - \Rightarrow t \qquad LT \qquad \Rightarrow 0$ $ R = -7$	Output [O] changes from (1) to (0) when Input [I] has been equal to (1) for time duration (t) Input [I] changes from (1) to (0), or optional Reset [R] changes to (1).	
	NONE		

Table 5.8 — Electrical schematic symbols

No	Symbol (1)	Description
1	O	 Device wiring point. Device wiring terminal.
2	(2)	 Normally open single circuit momentary pushbutton switch. Form A switch contact. Stack symbols to form multi-pole switches. Combine with symbols 5 or 6 to form toggle or rotary actuated switches.
3	(2)	 Normally closed single circuit momentary pushbutton switch. Form B switch contact. Stack symbols to form multi-pole switches. Combine with symbols 5 or 6 to form toggle or rotary actuated switches.
4	(2)	 Normally closed/normally open double circuit momentary pushbutton switch. Form C switch contact. Stack symbols to form multi-pole switches. Combine with symbols 5 or 6 to form toggle or rotary actuated switches
5	(3)	 Two-position toggle or rotary maintained position pushbutton switch actuator. Combine with symbols 2, 3, and 4 to form single or multi-pole switches.
6	(3)	 Three-position toggle or rotary maintained position pushbutton switch actuator. Combine with symbols 2, 3, and 4 to form single or multi-pole switches.
7	(4)	 Single-pole normally open toggle switch. Form A switch contact. Combine with symbols 10 thru 15.
8	(4)	 Single-pole normally closed toggle switch. Form B switch contact. Combine with symbols 10 thru 15.
9	(4)	 Double pole normally closed /normally open toggle switch. Form C switch contact. Combine with symbols 10 thru 15.
10		Rotary selector switch.

Table 5.8 — Electrical schematic symbols

		explanatory notes in Clause 5.3.8.
No	Symbol (1)	Description
11	(5)	Pressure switch actuator.
12	(5)	Differential pressure switch actuator.
13	(5)	Liquid level switch actuator.
14	(5)	Temperature switch actuator.
15	(5)	Flow switch actuator.
16	(5)	Foot switch actuator.
17	(*)	 Relay operating coil. (*) = Relay designator, such as: a. Instrument tag number if assigned. b. RO1, RO2, R4, R5, MR10, etc.
18	11	Normally open relay contact. Form A contact.
19	N.	Normally closed relay contact. Form B contact.
20	T _k	 Normally open, normally closed relay contact. Form C contact.

Table 5.8 — Electrical schematic symbols

No	Symbol (1)	Description
21	<u></u> (*)	 On time delay. Moves after relay coil is energized and set time has elapsed. (*) = Set time.
22	(*)	 Off time delay. Moves after relay coil de-energizes and set time has elapsed. (*) = Set time.
23	(*)	 Transformer. (*) = Rating, 220/120 Vac or Vdc, etc.
24	(6) a) (*) b) (*)	 Fuse, non-resettable. (*) = Rating, 2 A, 5 A, etc.
25	0000	Thermal overload.
26	°) (*)	 Circuit interrupter, 1-pole, manual reset. (*) = Rating, 10 A, 15 A, etc.
27	°) - °) (*)	 Circuit interrupter, 3-pole, manual reset. (*) = Rating, 15 A, 20 A, etc.
28	0)(*)	 Circuit breaker, 1-pole, manual reset. (*) = Rating, 20A, 30A, etc.
29	\$\frac{1}{2}\frac{1}{2	 Circuit breaker, 3-pole, manual reset. (*) = Rating, 20 A, 25 A, etc.
30		Bell.

Table 5.8 — Electrical schematic symbols

Symbol (1)	Description
	Horn or siren.
б	Buzzer.
o\vo	Solenoid coil.
	Pilot light.
	• Battery
=	• Ground
(6) a)	Connection conventions a) and b): Left = Not connected. Right = Connected.
	(6) a)

6 Graphic symbol dimension tables

- 6.1 Graphic symbols dimension tables
- 6.1.1 The following tables provide measurement units for dimensioning the geometric shapes that are required to construct the graphic symbols.
- 6.1.2 The shapes in the tables are drawn twice their normal minimum size for clarity.
- 6.1.3 Symbols shall be drawn to a:
 - a) Larger size, by increasing the dimensional unit, when required reduction of an original drawing or document results in an illegible diagram.
 - b) Smaller size, by decreasing the dimensional unit, when required by space limitations of an original drawing or document.
- 6.1.4 All the symbols shown in Clause 5 are not individually dimensioned, but the geometric shapes required to construct all the symbols from the graphic symbol tables are included.
- 6.1.5 The traditional minimum size for device and function symbols from Table 6.1, a 7/16-inch (10.5-millimeter) circle, may be increased to a less commonly used 1/2-inch (12-millimeter) circle.
- 6.2 Measurement units
- 6.2.1 The dimensions are represented by measurement units (m.u.) that, as a minimum, shall have equivalent dimensions equal to:
 - a) One-sixteenth inch (1/16 inch or 0.0625 inch).
 - b) One and one-half millimeters (1.50 millimeters).
- 6.2.2 Symbols drawn in any full size diagram shall be the product of the symbol's geometric shape m.u. times a selected equivalent dimension equal to or greater than the minimum equivalent dimension.
- 6.2.3 Lettering shown is the minimum size allowed for full size symbols.
- 6.3 Dimensions for graphic symbol tables explanatory notes
- 6.3.1 Table 6.1 Dimensions for measurement and control instrumentation device or function symbols, Tables 5.1.1 and 5.1.2
- (1) Dimension in parentheses is for 1/2-inch (12-millimeter) option for generic circle symbol.
- 6.3.2 Table 6.2 Dimensions for measurement symbols: primary elements and transmitters, Tables 5.2.1, 5.2.2, 5.2.3, 5.2.4, and 5.2.5
- (1) Dimension in parentheses is for 1/2-inch (12-millimeter) option for generic circle symbol.
- (2) Size as required by size of vessel as drawn or depth of application.

- (3) Dip tube shown, show as required for other devices.
- 6.3.3 Table 6.3 Dimensions for line symbols, Tables 5.3.1 and 5.3.2
- (1) Recommended maximum signal line thickness.
 - (a) Signal lines are never thicker than process and equipment lines.
- (2) Recommended minimum process and equipment line thickness for instrument sketches.
- (3) Clearance around symbol shall be equal to half the width of the symbol.
- 6.3.4 Table 6.4 Dimensions for final control elements, Tables 5.4.1, 5.4.2, 5.4.3, and 5.4.4.
- (1) Table does not require any additional notes.
- 6.3.5 Table 6.5 Dimensions for functional diagramming symbols, Table 5.5
- (1) Graphics shown for top-to-bottom signal flow.
- (2) Rotate graphics 90 degrees counterclockwise for left-to-right signal flow.
- 6.3.6 Table 6.6 Dimensions for signal processing function block symbols, Table 5.6
- (1) Small square graphic is used with graphics from Table 6.1.
- (2) Large rectangular graphic is used with graphics from Table 6.5.
- 6.3.7 Table 6.7 Dimensions for binary logic symbols, Table 5.7
- (1) Input connection line dimensions are the minimum for:
 - (a) Five inputs.
 - (b) Three inputs.
 - (c) Two inputs.
- (2) Two m.u.'s shall be added for each additional input
- (3) Minimum spacing between inputs.
- (4) Output signal line shall be centered on symbol.
- 6.3.8 Table 6.8 Dimensions for electrical schematic symbols, Table 5.8
- (1) Table does not require any additional notes.

Table 6.1 — Dimensions for Tables 5.1.1 and 5.1.2




Table 6.2 — Dimensions for Tables 5.2.1, 5.2.2, 5.2.3, 5.2.4, and 5.2.5




Table 6.3 — Dimensions for Tables 5.3.1 and 5.3.2




Table 6.4 — Dimensions for Tables 5.4.1, 5.4.2, 5.4.3, and 5.4.4




Table 6.5 — Dimensions for Table 5.5




Table 6.6 — Dimensions for Table 5.6




Table 6.7 — Dimensions for Table 5.7





Table 6.8 — Dimensions for Table 5.8



Annex A Identification system guidelines (informative annex)

- A.1 Identification system
- A.1.1 This informative annex to the standard describes a common and almost universally used Identification System for monitoring and control instrument devices and functions that is logical, unique, and consistent in application with a minimum of exceptions, special uses, or requirements.
- A.1.2 An identification system is required to identify instrumentation in text and in sketches and drawings when used with graphic symbols as described in Annex B.
- A.1.3 The Identification System provides methods for identifying instrumentation required to monitor, control, and operate a processing plant, unit operation, boiler, machine, or any other system that requires measurement, detection, indication, control, modulation, and/or switching of variables or states.
- A.1.4 The methods shown are based on the most common ones now in use in the chemical and refining process industries.
- A.1.5 Any different methods in use in these industries should be:
 - a) Revised to conform to this annex.
 - Submitted to ISA (email to standards@isa.org) to determine if they are to be:
 - 1) Included in the next revision of this standard.
- A.1.6 ISA should be advised of differences that are normal practice in other industries so that these methods can be incorporated into the next revision of this standard.
- A.1.7 A multi-component monitor or control loop consists of some or all of the following (as indicated):
 - a) Measurement or detection of process variable or state (monitor and control):
 - 1) Measurement element, such as an orifice plate or thermocouple.
 - 2) Measurement transmitter or indicator:
 - a) With an integral-measuring element, such as a pressure-actuated transmitter or gauge.
 - b) With a non-integral-measuring element, such as a thermocouple-actuated temperature transmitter or gauge.
 - b) Conditioning of measurement or input signal (monitor and control):
 - Calculating devices.
 - 2) Calculating functions.
 - c) Monitoring of process variable (monitor):
 - 1) Indicating or recording device.

- 2) Application software display function.
- d) Controlling of process variable (control):
 - 1) Indicating or recording control device.
 - 2) Application software control function.
- e) Conditioning of controller or output signal (control):
 - 1) Calculating devices.
 - 2) Calculating functions.
- f) Modulation of controlled variable (control):
 - 1) Control valve modulation or on-off action.
 - 2) Resetting another control loop setpoint.
 - 3) Limiting another control loop output signal.
- A.1.8 A loop number is assigned to each group of components required to perform the desired function of the monitor or control scheme.
- A.1.9 A single component monitor or control loop consists of some or all of the following:
 - a) Self-acting measuring and control devices, such as pressure or temperature control valves.
 - b) Self-acting measuring and control devices, such as pressure or temperature safety valves.
 - c) Single point monitoring devices, such as pressure or temperature gauges.
- A.1.10 Each single component may be assigned:
 - a) A unique loop number, indexed with the plant instrumentation.
 - b) An instrument tag number, indexed separate from the primary plant instrumentation.
 - c) A coded type number.
- A.2 Instrument index
- A.2.1 Loop Identification Numbers and Instrument Identification/Tag Numbers are recorded in an Instrument Index that should be maintained for the life of the facility for the recording and control of all documents and records pertaining to the loops and their instrumentation and functions.
- A.2.2 An Instrument Index should contain references to all instrumentation data required by owner and/or government regulatory agency management of change requirements and contain, as a minimum for each loop:

- a) Loop Identification Number.
- b) Service Description.
- c) Instrument Identification/Tag Numbers.
- d) Piping and Instrumentation Diagram drawing numbers.
- e) Instrument Data Sheet numbers.
- f) Location Plan drawing numbers.
- g) Installation Detail drawing numbers.
- A.3 Loop identification and instrument identification/tag numbers
- A.3.1 Loop Identification Numbers are unique combinations of letters and numbers that are assigned to each monitoring and control loop in a facility to identify the process or machine variable that is being monitored or controlled.
- A.3.2 Instrument Identification/Tag Numbers are unique combinations of letters and numbers that are formed by adding letters to the Loop Identification Number to define the purpose of each loop device and/or function that comprises a monitoring or control loop.
- A.3.3 Instrument Identification/Tag Numbers are also called Instrument Identification Number, Instrument Tag Number, Instrument Number, or Tag Number.
- A.3.4 Examples of Loop Identification and Instrument Identification/Tag Numbers for a typical loop with references to sub-clauses relevant to the components of the Loop and Instrument Identification/Tag Numbers are given in Table A.1 Typical Loop and Instrument Identification/Tag Numbers.
- A.4 Loop identification number
- A.4.1 A Loop Identification Number is a unique combination of letters and numbers that is assigned to each monitoring and control loop in a facility to identify the process or machine variable that is being monitored or controlled and should be assigned to each:
 - a) Primary monitoring and control loop.
 - b) Self-contained measuring or control device.
 - Secondary measuring or monitoring device if future primary loops are anticipated or if it is the standard practice of the User.
- A.4.2 Loop Identification Numbers assigned, as the basis for Instrument Identification/Tag Numbers to auxiliary or accessory devices, should be the same as the loop for which the devices are required.
- A.4.3 Loop Identification Numbers are assigned:
 - a) First Letters from Table 4.1 to identify loop Measured/Initiating Variables.

- b) Numerals to form a unique loop identity.
- Optional loop suffixes to identify identical loops on identical pieces of equipment or services.

A.5 Loop identification number letters

- A.5.1 Loop Identification Number letters should be selected from Table 4.1 to identify the loop Measured/Initiating Variable according to one of the following methods selected by the end user:
 - a) Measured/Initiating Variable: only a Measured/Initiating Variable is selected, such as analysis [A], flow [F], level [L], pressure [P], temperature [T], etc.
 - b) Measured/Initiating Variable with Variable Modifier: a Measured/Initiating Variable and, when applicable, a Variable Modifier is selected, such as analysis [A], flow [F], flow quantity [FQ], level [L], pressure [P], differential pressure [PD], temperature [T], differential temperature [TD], etc.
 - c) First-Letters: a Measured/Initiating Variable and, when applicable, a Variable Modifier, only if the resulting First-Letter combination defines a loop variable that can be measured directly, such as pressure differential [PD] as opposed to one that is mathematically derived, such as flow ratio [FF].
- A.5.2 A Measured/Initiating Variable in combination with the safety Variable Modifier [S] is always treated as a loop variable in each of the preceding selection methods to identify self-acting devices intended to protect against emergency conditions that may be hazardous to plant personnel, plant equipment, or the environment.
- A.5.3 A Measured/Initiating Variable is selected according to the physical or mechanical property that is being measured, derived or initiates an action and not according to the construction or mode of actuation of the measuring device or the property or the action it initiates:
 - a) A loop that controls pressure in a vessel by manipulating gas or vapor flow to or from the vessel is a pressure [P] loop and not a flow [F] loop.
 - b) A loop that measures pressure differential across:
 - 1) An orifice plate from which flow rate is calculated is a flow [F] loop and not a pressure [P] or pressure differential [PD] loop.
 - 2) A fluid interface in a vessel is a level [L] loop and not a pressure [P] or pressure differential [PD] loop.
 - 3) A filter bed or element is a pressure [P] or pressure differential [PD]-loop.

A.6 Loop identification number numerals

A.6.1 Loop Identification Number numerals should be assigned to loop measured variable letters according to one of the following methods selected by the end user:

- Parallel: duplicated numerical sequences for each loop variable letter or first letter combination.
- Serial: single numerical sequence regardless of loop variable letter or first letter combination.
- c) Parallel/Serial: parallel sequences for selected loop variable letters or first letter combinations and a serial sequence for the remainder.
- A.6.2 Loop Number numerical sequences are normally three or more digits, -*01, -*001, -*0001, etc. where the asterisk * can be :
 - a) Any digit from zero to 9.
- b) Coded digits related to drawing numbers, unit numbers, equipment numbers, etc.
- A.6.3 *00, *000, *0000, etc. should be used only for special, significant, or critical loops as defined by the User.
- A.6.4 000, 0000, 00000, etc. should not be used
- A.6.5 Loop Identification letters and numbers should be assigned in accordance with one of the following Loop Numbering Schemes:
 - a) No. 1 Parallel Measured/Initiating Variable.
 - b) No. 2 Parallel Measured/Initiating Variable with Variable Modifier.
 - c) No. 3 Parallel First Letter(s).
 - d) No. 4 Series Measured/Initiating Variable.
 - e) No. 5 Series Measured/Initiating Variable with Variable Modifier.
- f) No. 6 Series First Letter(s).
- g) No. 7 Parallel/Series Measured/Initiating Variable.
- h) No. 8 Parallel/Series Measured/Initiating Variable with Variable Modifier.
- i) No. 9 Parallel/Series First Letter(s).
- A.6.6 Gaps should be left in any sequence to allow for the addition of future loops.
- A.6.7 See Table A.2 Allowable letter/number combinations for, loop numbering schemes for examples of typical Loop Number assignments.
- A.7 Optional loop number prefixes
- A.7.1 Loop Number Prefixes consisting of any combination of alpha/numeric characters that may be added to Loop Numbers to identify loop location, such as a complex, plant, or unit should be located before the Measured/Initiating Variable, for example, a flow loop in processing plant #1 might be [PP1-F*01].

- A.7.2 Loop Number Prefixes should:
 - a) Not necessarily be shown on drawings or indexes but covered by a general note on a legend sheet or a note on each drawing or index sheet.
 - b) Be shown for all uses on drawings when more than one prefix is required by loops shown on the drawing.
 - c) Be shown when used in text.
- A.8 Instrument identification/tag number
- A.8.1 An Instrument Identification/Tag Number is a unique combination of letters and numbers that is assigned to define the purpose of each loop device and/or function that comprises a monitoring or control loop.
- A.8.2 Adding a Variable Modifier, if needed, and Succeeding Letters to the Loop Identification Number letters forms an Instrument Identification/Tag Number.
- A.8.3 Instrument Identification/Tag Numbers may also be called Instrument Identification Number, Instrument Tag Number, Instrument Number, or Tag Number.
- A.9 Function identification letters
- A.9.1 Instrument Function Identification letters should be selected from Table 4.1, Identification Letters, and added to the Loop Identification Number letters to form an Instrument Functional Identity.
- A.9.2 The sequence of letters in a Functional Identification should be in the same left-to-right order as the columns in Table 4.1:
 - a) Measured or Initiating Variable, from Column 1.
 - b) Modifier, if required, from Column 2.
 - c) Passive Readout Function, from Column 3.
 - d) Active Output Function, from Column 4.
 - e) Modifier(s), if required, from Column 5.
- A.9.3 Functional Identifications should use one Readout/Passive Function or one Output/Active Function to identify each device or function except, as is common for:
 - a) Indicating /recording controller/switch instruments or functions in which one Passive Function, indicate [I] or record [R] and one Active Function, control [C] or switch [S], is combined to form, for example, pressure recording controller [PRC], or low-pressure indicating switch [PISL].
 - b) Self-actuated control valves, in which two Active Functions control [C] and valve [V] are combined to form, for example, pressure control valve [PCV].

- A.9.4 The number of letters in a Functional Identification should be sufficient to fully describe the functionality of the device or function being identified, but generally should not exceed eight.
- A.9.5 Function Modifiers designate the relative value of the measured or initiating variable that actuates the instrument or function, for example for Function Modifier low [L]:
 - a) [PSL-*01] indicates actuation by a pressure below a setpoint, normally used to indicate a process level that requires operator intervention to prevent a process trip or other unwanted result.
- b) [PSLL-*01] indicates actuation below a setpoint lower than the previous example, normally used to indicate a process level that resulted in a process trip.
- A.9.6 A device or function common to two or more loops should be assigned a Loop Identification Letter for the loop which actuates the instrument:
 - a) A solenoid valve that is actuated by a high level switch [LSH] to trip a flow control valve [FV] is assigned to the level [L] loop as an [LY] and not to the flow [F] loop as an [FY].
 - b) A high signal select device or function that selects the higher signal from a flow [F] loop and a high level [L] override loop is assigned to the flow [F]-loop as an [FY] and not to the level [L] loop as an [LY].
- A.9.7 For allowable function letter combinations see tables:
 - a) A.3.1 Allowable succeeding letter combinations for readout/passive function letters.
 - b) A.3.2 Allowable succeeding letter combinations for output/active function letters.
- A.10 Loop number and instrument/tag number suffixes
- A.10.1 A Loop Number Suffix may be added to a Loop Number to identify identical loops on identical equipment in the same processing unit when the service or equipment is assigned the same equipment identification number with a suffix, such as reactors, heat exchangers, and pumps.
- A.10.2 A Loop Suffix may use alphabetic or numeric characters according to User/Owner established practice and should be located after the Loop Identification Number as illustrated in Table A.1.
- A.10.3 A Loop Suffix may be located after the Loop Letters when user, owner, computer, or microprocessor information systems will not allow alphabetic or additional numeric characters in the numerical part of an identification number:
- A.10.4 An Identification/Tag Number Suffix should be added to Instrument Identification/Tag Numbers in the loop to designate two or more similar devices or functions:
 - a) Case 1 in different services, such as control valves that direct flow to different places, or auxiliary devices, such as those that perform different functions.
 - b) Case 2 in the same service, such as control valves that direct flow to the same place, or auxiliary devices, such as those that perform the same function.
- A.10.5 Additional Identification/Tag Number Suffixes should be added when two or more similar devices or functions are also duplicated, using alternating alpha/numeric characters.

- A.10.6 For examples of Loop Number and Instrument/Tag Number Suffixes, see Table A.4.
- A.11 Optional punctuation marks in identification numbers
- A.11.1 Punctuation marks, hyphens, slashes, etc., may be used to separate sections of identification numbers as required by:
 - a) User/Owner.
 - b) Database management system.
- c) Control system application software.
- A.11.2 Punctuation is recommended for use between:
 - a) An alphabetic Loop Number prefix and Measured/Initiating Variable letters: [AB-P*05].
 - b) Loop Number numerals and a numeric Loop Number suffix: [AB-P***05-1**, AB-P***05-2**],
 - c) Loop Number numerals and Tag Number suffix: [10-P*05-A1A or 10-P*05-1A1]
 - d) A Loop Number suffix and Tag Number suffix: [10PT*05**A-A** or 10PT*05-**1-A**].
- A.11.3 Punctuation is optional for use between:
 - a) A Numeric Loop Number prefix and Measured/Initiating Variable letter: [10-P*05].
- b) A Measured /Initiating Variable letter and Loop Number numerals: [10**P*-05**].
- A.11.4 Punctuation should not be used between:
 - a) Loop Number numerals and an alphabetic Loop Number suffix: [10P***05A**].
- b) Additional Tag Number suffixes: [10PV*05A**-A1A**].
- A.11.5 Backslashes are normally used between Functional Identification letters for multifunction devices when used in text, [TR/TSH-*108].
- A.12 Multivariable, multifunction, and multipoint loops
- A.12.1 Loops that have more than one input and/or output are classified as:
 - a) Multivariable: when two or more Measured/Initiating Variables of the same or different kinds generate one Output/Active Function and one or more Readout/Passive Functions.
 - b) Multifunction: when one Measured/Initiating Variable generates two or more Output/Active or Readout/Passive Functions.
 - c) Multivariable/multifunction: when two or more Measured/Initiating Variables of the same or different kinds generates two or more Output/Active or Readout/Passive Functions..

- d) Multipoint: when two or more Measured/Initiating Variables of the same or different kinds generate two or more Readout/Passive Functions.
- A.12.2 Multivariable Loop Number assignments using pressure [P-*07], temperature [T-*03], and speed [S-*02] loops, for example, should be either:
 - a) Alphabetically ordered Measured/Initiating Variables with Loop Number numerals the same as or different from the leading Measured/Initiating Variable: [PTS-*07] or [PTS-*10].
- b) Multivariable Measured/Initiating Variable [U]: [U-*01]
- A.12.3 Multivariable Loop components should be assigned Instrument/Tag Numbers as an example for:
 - a) Inputs: [PT-*07], [TT-*03], and [ST-*02].
 - b) Output: either [PTSV*07], [PTSV-*10], or [UV-*01].
- A.12.4 Multifunction Instrument/Tag Number assignments using a flow [F] loop with indicating [I], controlling [C], and switching [S] functions, for example, should be either [FICS-*05].or [FU-*05].
- A.12.5 Multivariable/multifunction Loop Number assignments using flow [F-*05], pressure [P-*07], temperature [T-*03], and speed [S-*02] loops, for example, should be either:
 - a) Alphabetically ordered Measured/Initiating Variables with Loop Number numerals the same as or different from the leading Measured/Initiating Variable: [FPTS-*05] or [FPTS-*10].
- b) Multivariable Measured/Initiating Variable [U]: [U-*01]
- A.12.6 Multivariable/Multifunction Loop components should be assigned Instrument/Tag Numbers as an example for:
 - a) Inputs: [FT-*05], [PT-*07], [TT-*03], and [ST-*02].
- b) Output: either [PTSV*07] or [PTSV-*10], and [FV-*05], or [UV-*01A] and [UV-*01B].
- A.12.7 Multipoint Loop and Instrument/Tag Number identification letter assignments for :
- a) Single Measured/Initiating Variable, using temperature [T] as an example, should be:
 - 1) Loop Number: [T-*11].
 - 2) Input: [TE-*11-01], [TE-*11-02], etc. or [TJE]-*11-01, [TJE-*11-02], etc.
 - 3) Readout: [TI-*11] or [TJI-*11]
 - 4) Readout point; [TI-*11-01], [TI-*11-02], etc. [TJI-*11-01], [TJI-*11-02], etc.
- b) Multiple Measured/Initiating Variables, using pressure [P] and temperature [T] as an example, should be:
 - 1) Loop Number: [PT-*11] or [U-*01].
 - 2) Input: [PT-*11-01], [TE-*11-02], etc. or [PJT-*11-01], [TJE-*11-02], etc.
 - 3) Readout: [PTI-*11] or [PTJI-01] or [UI-*01] or [UJI-*01].

- 4) Readout point: [PI-11-01], [TI-11-02], etc. or [PJI-11-01], [TJI-11-02], etc.
- A.13 Secondary, auxiliary, and accessory instrumentation
- A.13.1 Secondary instrumentation, such as level glasses, pressure gauges, and thermometers, may be assigned either:
 - a) An Instrument Identification/Tag Number which should be either of:
 - 1) LG-*01, PG-*01, TG-*01, etc.
 - 2) LI-*01, PI-*01, TI-*01, etc.
 - b) A generic identification number that defines the instrument type and range which should be either of:
 - 1) LG-24 0-24in, PG-200 0-200psig, TG-250 0-250degF.
 - 2) LI-24 0-24in, PI-200 0-200psig, TI-250 0-250degF.
- A.13.2 Readout/Passive Function letter for glass, gauge, or viewing device [G] is recommended for use for flow glasses [FG], level glasses or gauges [LG], pressure gauges [PG], thermometers [TG], etc., to avoid database management problems with primary flow indicators [FI], level indicators [LI], pressure indicators [PI], temperature indicators [TI], etc.
- A.13.3 Current common usage is [FG] and [LG] for flow and level and [PI] and [TI] for pressure and temperature.
- A.13.4 Auxiliary instrumentation, such as signal computing and converting relays, solenoid valves, and analyzer sample conditioning units, are identified by a loop Measured/Initiating Variable and the Output/Active Function [Y], as in, [FY], [PY], etc.
- A.13.5 Instrumentation accessories, such as flowmeter runs, purge meters, air sets, seal pots, etc., that may or may not be explicitly shown on a diagram should be tagged in the Instrument index.
- A.13.6 A purge meter for pressure transmitter [PT-*23] may be tagged:
 - a) With the Instrument Identification/Tag Number of the instrument they serve followed by a word or phrase, that describes their function, for example: [PT-*23 PURGE].
 - b) With an Instrument Identification/Tag Number as a component of the loop: [PX-*23] with a note outside the bubble or in the note section of the drawing describing its use.
 - c) As a secondary instrument:
 - 1) [FI-*11] if not controlling purge flow.
 - 2) [FICV-*11] if controlling purge flow.
- A.13.7 Assignment of a tag number to an accessory;
 - a) Means that it must be listed in the instrument index.

- b) Does not mean that it must be shown on a P&ID.
- c) Means that it must be tagged on a P&ID if shown.
- A.13.8 The identification methods chosen for a project should be documented in the Owners or Users engineering and design standards and guidelines and on a drawing or document legend sheet.

A.14 System identification

- A.14.1 Instrumentation is often assembled into systems for various reasons, such as ease of purchase, ease of application, and compatibility, and these systems may need to be identified on drawings and in text.
- A.14.2 Some of the more common instrumentation systems and the system codes often used to identify them are:
- a) ACS Analyzer Control System b) BMS **Burner Management System** c) CCS Computer Control System Continuous Emissions Monitoring System d) **CEMS** DCS Distributed Control System e) = f) MMS Machine Monitoring System = **PCCS** Personal Computer Control System = g) **PLC** Programmable Logic Controller h) = i) SIS Safety Instrumented System
- A.14.3 Suffixes may be added to the instrumentation system codes [SC]:
 - a) [SC 1, SC 2], etc., when more than one system is used in a complex.

Vibration Monitoring System

- b) [SC-M, SC-L], when main and local systems are used in a unit.
- c) [SC-'unit identifier'], when system is dedicated to a single unit in a multi-unit facility.
- A.15 Identification system guideline tables

VMS

j)

- A.15.1 Identification System guideline tables are based on the most common usages to be found in the chemical and refining process industries.
- A.15.2 The tables are intended to be a guide to constructing such tables based on a User's actual requirements.

- A.15.3 Loops are based on the variable being measured and not on the variable being manipulated.
- A.15.4 Instrument tag numbers are based on the loop number and the functionality required of the loop components.
- A.16 Identification system guideline table explanatory notes

The following notes, indicated in Tables A.1, A.2, A.3, and A.4 by parentheses, are used as an aid in understanding the meanings and usage of the lettering.

- A.16.1 Table A.1 Typical Loop and Instrument Identification/Tag Numbers
- (1) Replace asterisk in Loop Numbers with any digit from 0 to 9 or any combination of digits.
- (2) Numbers in brackets indicate sub-clause relevant to line description.
- A.16.2 Table A.2 Allowable letter/number combinations for loop numbering schemes.
- (1) First Letters do not include all possibilities.
- (2) Replace asterisk in Loop Number with any digit from 0 to 9 or any combination of numerals.
- (3) Variable Modifier safety instrumented system [Z] is technically not a direct-measured variable but is used to identify loops in a Safety Instrumented System. And because of the critical nature of such loops, any Measured/Initiating Variable followed by [Z], such as [FZ], [PZ], and [TZ], should be considered as Measured/ Initiating Variables in all Loop Identification Number construction schemes
 - (a) An alternate method for identifying Safety Instrumented System loops is to append [(SIS)] outside the bubbles of Safety Instrumented System loops and as a prefix or suffix to the Loop Number when used in text. For example, Loop Numbers for pressure and temperature loops in an SIS may be [(SIS)P-*01] or [T-*09(SIS)].
- (4) Users should assign, as needed, meanings to:
 - (a) Users Choice Measured/Initiating Variable letters [C], [D], [G], [M], [N], and [O].
 - (b) Variable Modifier letter blanks [A], [B], [C], [E], [G], [H], [I], [L], [M], [N], [O], [P], [T], [U], [V], and [W].
- (5) Variable Modifier safety [S] is technically not a direct-measured variable but is used to identify self-actuated emergency protective primary and final control elements only when used in conjunction with Measured/Initiating Variables flow [F], pressure [P] or temperature [T]. And because of the critical nature of such devices, [FS], [PS], and [TS] should be considered as Measured/Initiating Variables in all Loop Identification Number construction schemes:
 - (a) Shall not be used to identify Safety Instrumented Systems and components.
- (6) Measured/Initiating Variables [V], [W], or [Z] when used in a Safety Instrumented System and:
 - (a) Not axially oriented should use [VZ], [WZ], and [ZZ] as Measured/Initiating Variables.

- (b) Axially oriented should use [VZX], [VZY], [VZZ], and [WZX], [WZY], [WZZ] and [ZZX], [ZZY], [ZZZ] as Measured/Initiating Variables.
- A.16.3 Tables A.3.1 and A.3.2 Allowable succeeding letter combinations for readout/passive and output/active function letters and first-letters.
- (1) Cells marked NA indicate not allowable combinations.
- (2) First Letters are assigned according to Table A.2.
- (3) Function Modifiers are added where indicated to right of alarm function combinations.
- (4) Users should assign, as needed, meanings to:
 - (a) Users Choice Function letters [B] and [N].
 - (b) Readout/Passive Function blanks [C], [D], [F], [H], [J], [K], [M], [S], [T], [V], [Y], and [Z].
 - (c) Output/Active Function blanks [A], [D], [E], [F], [G], [H], [I], [J], [L], [M], [O], [P], [Q], [R], and [W].
 - (d) Function Modifier blanks [A], [E], [F], [G], [I], [J], [K], [P], [Q], [T], [U], [V], [W], [Y], and [Z].
- (5) Readout/Passive Function [G] (glass, gauge) is used for local direct connected devices, such as flow sight glasses, level glasses, pressure gauges, thermometers weigh scales and position indicators. These devices provide a simple view of a process condition.
 - (a) Readout/Passive Function [I] (indicate) may continue to be used in facilities where it is currently used.
- (6) Pressure rupture disc [PSE] and fusible link [TSE] apply to all sensors or primary elements intended to protect against emergency pressure or temperature conditions.
- (7) The combinations in the [C] column are used for:
 - (a) Discrete single case instruments that do not have operator-visible indication of measured variable, setpoint, or output signal.
 - (b) Controller functions configured in shared display, shared control systems where indication and recording are configurable functions available on demand.
- (8) The combinations in the [IC] and [RC] columns indicate the order to be followed in forming the Functional Identification of a controller device or function that also provides indication or recording.
- (9) The combinations in the [CV] column indicate the order to be followed in forming the Functional Identification for self-actuated control valves.
- (10) Flow safety valve [FSV] applies to valves intended to protect against an emergency excess flow or loss of flow condition. Pressure safety valve [PSV], and temperature safety valve [TSV] apply to valves intended to protect against emergency pressure and temperature conditions
- (11) A self-actuated pressure valve that prevents operation of a fluid system at a higher-than-desired pressure by bleeding fluid from the system is a backpressure control valve [PCV], even if the valve is not normally used.

(a) This valve should be designated a pressure safety valve [PSV] if it protects against emergency conditions hazardous to personnel and/or equipment that are not expected to arise normally.

A.16.4 Table A.4 — Loop and Identification Tag Number suffixes

- (1) Replace asterisk in Loop Numbers with any digit from 0 to 9 or any combination of numerals.
- (2) Punctuation shown is recommended.
- (3) Case 1 and Case 2 may be reversed or a single case may be used for all applications.

Table A.1 — Typical Loop and Instrument Identification/Tag Numbers

					Е	xamp	le: Di	fferen	tial p	ressu	re loo	o with a low alarm.			
				Ty	ypical							Number – 10-P-*01A (1) s: 1, 4, or 7)			
10	-	Р	-	*01	Α							Loop Identification Number	[A.4] (2)		
					Α						Α	Loop Number Suffix	[A.10]		
				*01							*01	Loop Identification Number numerals	[A.6]		
			-								-	Optional Punctuation	[A.11]		
		Р									Р	Measured/Initiating Variable letter	[A.5]		
	-	- Optional Punctuation													
10											10	Loop Number Prefix	[(A.7)]		
				_	1							- AB-PD-*01A (1) 3, 5 , 6, 8, or 9)			
AB	-	Р	D	-	*01	Α						Loop Identification Number	[A.4] (2)		
	A Loop Number Suffix *01 *01 Loop Identification Number numerals														
					*01						*01	Loop Identification Number numerals	[A.6]		
				-							-	Optional Punctuation	[A.11]		
			D								D	Variable Modifier letter	[A.5]		
		Р									Р	Measured/Initiating Variable letter	[A.5]		
		Р	D								PD	First Letters	[A.5]		
	-										-	Recommended Punctuation	[A.11]		
AB											AB	Loop Number Prefix	[A.7]		
	AB Loop Number Prefix [A.7] Typical Instrument Identification/Tag Number – 10-PDAL-*01A-1A1 (1)														
10	-	Р	D	Α	L	-	*01	Α	-	1	A1	Instrument Identification/Tag Number	[A.8] (2)		
											A1	Additional Tag Number Suffixes	[A.10]		
										1	1	First Tag Number Suffix	[A.10]		
	-								-		-	Recommended Punctuation	[A.11]		
								Α			Α	Loop Number Suffix	[A.10]		
							*01				*01	Loop Identification Number numerals	[A.6]		
						-					-	Optional Punctuation	[A.11]		
					L						L	Function Modifier letter	[A.9]		
				Α							Α	Function Identification letter	[A.9]		
				Α	L						AL	Succeeding Letters	[A.9]		
			D								D	Variable Modifier letter (if required)	[A.5]		
		Р									Р	Measured/Initiating Variable letter	[A.5]		
		Р	D	Α	L				-		PDAL	Function Identification letters	[A.9]		
	-										-	Optional Punctuation	[A.11]		
10											10	Loop Number Prefix	[A.7]		

ANSI/ISA-5.1-2009 - 100 -

Table A.2.1 — Allowable letter/number combinations for loop numbering schemes and first letters A to O

	First Letters (1)	Scheme 1	Scheme 2	Scheme 3	Scheme 4	Scheme 5	Scheme 6	Sche	me 7	Sche	me 8	Sche	me 9
	(.,		Parallel (2)			Serial (2)		Parallel (2)	Serial (2)	Parallel (2)	Serial (2)	Parallel (2)	Serial (2)
N	leasured/Initiating Variables	Meas / Ini	it Variable	First Letters	Meas / Ini	t Variable	First Letters		Measured/Init	iating Variable		First L	-44
	w/ and w/o Modifiers (4b)	w/o Mod.	w/Mod.	FIISI Letters	w/o Mod.	w/Mod.	riisi Letters	w/o Mo	difiers	w/Mod	difiers	FIISUL	ellers
Α	2Analysis	A-*01	A-*01	A-*01	A-*01	A-*01	A-*01	A-*01		A-*01		A-*01	
ΑZ	Analysis(SIS) (3)	A- 01	AZ-*02	AZ-*01	A- 01	AZ-*02	AZ-*02	A- 01		AZ-*02		AZ-*01	
В	Burner, Combustion	B-*01	B-*01	B-*01	B-*02	B-*03	B-*03		B-*01		B-*01		B-*01
BZ	Burner, Combustion(SIS) (3)	D- 01	BZ-*02	BZ-*01	D- 02	BZ-*04	BZ-*04		D- 01		BZ-*02		BZ-*02
С	User's Choice (4a)	C-*01	C-*01	C-*01	C-*03	C-*05	C-*05		C-*02		C-*03		C-*03
D	User's Choice (4a)	D-*01	D-*01	D-*01	D-*04	D-*06	D-*06		D-*03		D-*04		D-*04
Е	Voltage	E-*01	E-*01	E-*01	E-*05	E-*07	E-*07		E-*04		E-*05		E-*05
EZ	Voltage(SIS) (3)	L- VI	E-*02	EZ-*01	L- 00	E-*08	E-*08		L- 04		EZ-*06		EZ-*06
F	Flow, Flow Rate		F-*01	F-*01		F-*09	F-*09			F-*01		F-*01	
FF	Flow Ratio		FF-*02	FF-*01		FF-*10	FF-*10			FF-*02		FF-*01	
FQ	Flow Total	F-*01	FQ-*03	FQ-*01	F-*06	FQ-*11	FQ-*11	F-*01		FQ-*03		FQ-*01	
FS	Flow Safety (5)		FS-*04	FS-*01		FS-*12	FS-*12			FS-*04		FS-*01	
FZ	Flow(SIS) (3)		FZ-*05	FZ-*01		FZ-*13	FZ-*13			FZ-*05		FZ-*01	
G	User's Choice (4a)	G-*01	G-*01	G-*01	G-*07	G-*14	G-*14		G-*05		G-*07		G-*07
Н	Hand	H-*01	H-*01	H-*01	H-*08	H-*15	H-*15		H-*06		H-*08		H-*08
HZ	Hand(SIS) (3)	11- 01	HZ-*01	HZ-*01	11- 00	HZ-*16	HZ-*16		11- 00		HZ-*09		HZ-*09
- 1	Current	I-*01	I-*01	I-*01	I-*09	I-*17	I-*17		I-*07		I-*10		I-*10
ΙZ	Current(SIS) (3)	1- 01	IZ-*02	IZ-*01	1- 03	IZ-*18	IZ-*18		1- 07		IZ-*11		IZ-*11
J	Power		J-*01	J-*01		J-*19	J-*19				J-*12		J-*12
JQ	Power Totalize	J-*01	JD-*02	JD-*01	J-*10	JD-*20	JD-*20		J-*08		JQ-*13		JQ-*13
JZ	Power(SIS) (3)		JZ-*03	JZ-*01		JZ-*21	JZ-*21				JZ-*14		JZ-*14
K	Time, Schedule	K-*01	K-*01	K-*01	K-*11	K-*22	K-*22		K-*09		K-*15		K-*15
KQ	Time Totalize	10 01	KQ-*02	KQ-*01	10 11	KQ-*23	KQ-*23		100		KQ-*16		KQ-*16
L	Level	L-*01	L-*01	L-*01	L-*12	L-*24	L-*24	L-*01		L-*01		L-*01	
LZ	Level(SIS) (3)		LZ-*02	LZ-*01		LZ-*25	LZ-*25	L- VI		LZ-*02		LZ-*01	
М	User's Choice (4a)	M-*01	M-*01	M-*01	M-*13	M-*26	M-*26		M-*10		M-*17		M-*17
N	User's Choice (4a)	N-*01	N-*01	N-*01	N-*14	N-*27	N-*27		N-*11		N-*18		N-*18
0	User's Choice (4a)	O-*01	O-*01	O-*01	O-*15	O-*28	O-*28		O-*12		O-*19		O-*19

- 101 - ANSI/ISA-5.1-2009

Table A.2.2 — Allowable letter/number combinations for loop numbering schemes and first letters P to VZZ

	First Letters (1)	Scheme 1	Scheme 2	Scheme 3	Scheme 4	Scheme 5	Scheme 6	Sche	me 7	Sche	me 8	Sche	me 9
	.,		Parallel (2)			Serial (2)	•	Parallel (2)	Serial (2)	Parallel (2)	Serial (2)	Parallel (2)	Serial (2)
	leasured/Initiating Variables	Meas / Ini	t Variable	First Letters	Meas / Ini	t Variable	Firet Letters		Measured/Init	iating Variable		First L	attava
	w/ and w/o Modifiers (4b)	w/o Mod.	w/Mod.	FIRST Letters	w/o Mod.	w/Mod.	First Letters	w/o Mo	difiers	w/Mod	difiers	FIRST	etters
Р	Pressure		P-*01	P-*01		P-*29	P-*29			P-*01		P-*01	
PD	Pressure Differential		PD-*02	PD-*01		PD-*30	PD-*30			PD-*02		PD-*01	
PF	Pressure Ratio		PF-*03	PF-*01		PF-*31	PF-*31			PF-*03		PF-*01	
PJ	Pressure Scan	P-*01	PJ-*04	PJ-*01	P-*16	PJ-*32	PJ-*32	P-*01		PJ-*04		PJ-*01	
PK	Pressure Rate of Change		PK-*05	PK-*01		PK-*33	PK-*33			PK-*05		PK-*01	
PS	Pressure Safety (5)		PS-*06 PZ-*07	PS-*01		PS-*34	PS-*34			PS-*06 PZ-*07		PS-*01	
PZ	Pressure(SIS) (3)		PZ- 07	PZ-*01		PZ-*35	PZ-*35			PZ- 07		PZ-*01	
Q	Quantity	Q-*01	Q-*01	Q-*01	Q-*17	Q-*36	Q-*36		Q-*13		Q-*20		Q-*20
QQ	Quantity Totalize	Q- 01	QQ-*02	QQ-*01	Q- 17	QQ-*37	QQ-*37		Q- 13		QQ-*21		QQ-*21
R	Radiation		R-*01	R-*01		R-*38	R-*38				R-*22		R-*22
RQ	Radiation Totalize	R-*01	RQ-*02	RQ-*01	R-*18	RQ-*39	RQ-*39		R-*14		RQ-*23		RQ-*23
RZ	Radiation(SIS) (3)		RZ-*03	RZ-*01		RZ-*40	RZ-*40				RZ-*24		RZ-*24
S	Speed, Frequency	S-*01	S-*01	S-*01	S-*19	S-*41	S-*41		S-*15		S-*25		S-*25
SZ	Speed(SIS) (3)	3- 01	SZ-*02	SZ-*01	3- 19	SZ-*42	SZ-*42		3- 13		SZ-*26		SZ-*26
T	Temperature		T-*01	T-*01		T-*43	T-*43			T-*01		T-*01	
TD	Temperature Differential		TD-*02	TD-*01		TD-*44	TD-*44			TD-*02		TD-*01	
TF	Temperature Ratio		TF-*03	TF-*01		TF-*45	TF-*45			TF-*03		TF-*01	
TJ	Temperature Scan	T-*01	TJ-*04	TJ-*01	T-*20	TJ-*46	TJ-*46	T-*01		TJ-*04		TJ-*01	
TK	Temperature Rate of Change		TK-*05	TK-*01		TK-*47	TK-*47			TK-*05		TK-*01	
TS	Temperature Safety (5)		TS-*06 TZ-*07	TS-*01		TS-*48	TS-*48			TS-*06 TZ-*06		TS-*01	
TZ	Temperature(SIS) (3)		12-"07	TZ-*01		TZ-*49	TZ-*49			12-"06		TZ-*06	
U	Multivariable		U-*01	U-*01		U-*50	U-*50				U-*27		U-*27
UJ	Multivariable Scan	U-*01	UJ-*02	UJ-*01	U-*21	UJ-*51	UJ-*51		U-*16		UJ-*28		UJ-*28
UZ	Multivariable(SIS) (3)		UZ-*03	UZ-*01		UZ-*52	UZ-*52				UJ-*29		UJ-*29
V	Vibration, Machinery Analysis		V-*01	V-*01		V-*53	V-*53				V-*30		V-*30
VZ	Vibration(SIS) (3) (6a)		VZ-*02	VZ-*01		VZ-*54	VZ-*54				VZ-*31		VZ-*31
VX	Vibration X-Axis		VX-*03	VX-*01		VX-*55	VX-*55				VX-*32		VX-*32
VY	Vibration Y-Axis	V/ *O1	VY-*04	VY-*01	V-*22	VY-*56	VY-*56		V-*17		VY-*33		VY-*33
VZ	Vibration Z-Axis	V-*01	VZ-*05	VZ-*01	V- ZZ	VZ-*57	VZ-*57		V- 17		VZ-*34		VZ-*34
VZX	Vibration X-Axis(SIS) (3) (6b)		VZX-*06	VZX-*01		VZX-*58	VZX-*58				VZX-*35		VZX-*35
VZY	Vibration Y-Axis(SIS) (3) (6b)		VZY-*07	VZY-*01		VZY-*59	VZY-*59				VZY-*36		VZY-*36
VZZ	Vibration Z-Axis(SIS) (3) (6b)		VZZ-*08	VZZ-*01		VZZ-*60	VZZ-*60				VZZ-*37		VZZ-*37

ANSI/ISA-5.1-2009 - 102 -

Table A.2.3 — Allowable letter/number combinations for loop numbering schemes and first letters W to ZDZ

11010.11	umbers in parentheses refer to First Letters (1)	Scheme 1	Scheme 2	Scheme 3	Scheme 4	Scheme 5	Scheme 6	Sche	me 7	Schei	me 8	Sche	me 9
	That Letters (1)		Parallel (2)	ı		Serial (2)	1	Parallel (2)	Serial (2)	Parallel (2)	Serial (2)	Parallel (2)	Serial (2)
М	easured/Initiating Variables	Meas / Ini	it Variable	F:	Meas / Ini	t Variable	F: 41 44	` , ,		ating Variable		-: · · ·	
	w/ and w/o Modifiers (4b)	w/o Mod.	w/Mod.	First Letters	w/o Mod.	w/Mod.	First Letters	w/o Mo	difiers	w/Mod	lifiers	First L	.etters
W	Weight, Force		W-*01	W-*01		W-*61	W-*61				W-*38		W-*38
WZ	Force(SIS) (3) (6a)		WZ-*02	WZ-*01		WZ-*62	WZ-*62				WZ-*39		WZ-*39
WD	Weight Differential		WD-*03	WD-*01		WD-*63	WD-*63				WD-*40		WD-*40
WF	Weight Ratio		WF-*04	WF-*01		WF-*65	WF-*65				WF-*41		WF-*41
WK	Weight Loss (Gain)		WK-*05	WK-*01		WK-*66	WK-*66				WK-*42		WK-*42
WQ	Weight Total	W-*01	WQ-*06 WX-*07	WQ-*01	W-*23	WQ-*67	WQ-*67		W-*18		WQ-*43		WQ-*43
WX	Force X Axis	VV- U1	WY-*08	WX-*01	VV- 23	WX-*68	WX-*68		VV- 10		WX-*44		WX-*44
WY	Force Y Axis		WZ-*09	WY-*01		W-Y*69	W-Y*69				WY-*45		WY-*45
WZ	Force Z Axis		WZ-*10	WZ-*01		WZ-*70	WZ-*70				WZ-*46		WZ-*46
WZX	Force X Axis(SIS) (3) (6b)		WZX-*11	WZX-*01		WZX-*71	WZX-*71				WZX-*47		WZX-*47
WZY	Force Y Axis(SIS) (3) (6b)		WZY-*12	WZY-*01		WZY-*72	WZY-*72				WZY-*48		WZY-*48
WZZ	Force Z Axis(SIS) (3) (6b)		WZZ-*13	WZZ-*01		WZZ-*73	WZZ-*73				WZZ-*49		WZZ-*49
X	Unclassified	X-*01	X-*01	X-*01	X-*24	X-*74	X-*74		X-*19		X-*50		X-*50
Υ	Event, State, Presence	Y-*01	Y-*01	Y-*01	Y-*25	Y-*75	Y-*75		Y-*20		Y-*51		Y-*51
YZ	Event, State(SIS) (3)	1-01	YZ-*02	YZ-*01	1- 25	YZ-*76	YZ-*76		1- 20		YZ-*52		YZ-*52
Z	Position, Dimension		Z-*01	Z-*01		Z-*77	Z-*77				Z-*53		Z-*53
ZZ	Position(SIS) (3) (6a)		ZZ-*02	ZZ-*01		ZZ-*78	ZZ-*78				ZX-*54		ZX-*54
ZX	Position X Axis		ZX-*03	ZX-*01		ZX-*79	ZX-*79				ZY-*55		ZY-*55
ZY	Position Y Axis		ZY-*04	ZY-*01		ZY-*80	ZY-*80				ZZ-*56		ZZ-*56
ZZ	Position Z Axis		ZZ-*05	ZZ-*01		ZZ-*81	ZZ-*81				ZZ-*57		ZZ-*57
ZZX	Position X Axis(SIS) (3) (6b)	Z-*01	ZZX-*06	ZZX-*01	Z-*26	ZZX-*82	ZZX-*82		Z-*21		ZZX-*58		ZZX-*58
ZZY	Position Y Axis(SIS) (3) (6b)	2-01	ZZY-*07	ZZY-*01	2- 20	ZZY-*83	ZZY-*83		Z- Z1		ZZY-*59		ZZY-*59
ZZZ	Position Z Axis(SIS) (3) (6b)		ZZZ-*08	ZZZ-*01		ZZZ-*84	ZZZ-*84				ZZZ-*60		ZZZ-*60
ZD	Position Difference		ZD-*09	ZD-*01		ZD-*85	ZD-*85				ZD-*61		ZD-*61
ZDX	Position Difference X Axis		ZDX-*10	ZDX-*01		ZDX-*86	ZDX-*86				ZDX-*62		ZDX-*62
ZDY	Position Difference Y Axis		ZDY-*11	ZDY-*01		ZDY-*87	ZDY-*87				ZDY-*63		ZDY-*63
ZDZ	Position Difference Z Axis		ZDZ-*12	ZDZ-*01		ZDZ-*88	ZDZ-*88				ZDZ-*64		ZDZ-*64

- 103 - ANSI/ISA-5.1-2009

Table A.3.1.1 — Allowable succeeding letters for readout/passive functions aand ffirst letters A to O (1) (4b)

NOLE.	Numbers in parenthes	es reier to	Α Α	ry notes in	B B	E E	G	l ı l	1	N	0	P	Q	R	W	Х
	First Letters (2)	Absolute	Function	Deviation		_ L							ų ų	IX	**	- ^-
Mea	sured/Initiating Variables	Absolute	Modifier	Alarm	User's Choice	Primary Element	Gauge, Glass	Indicate	Light	User's Choice	Orifice, Restrict-	Point (Test	Integrate, Total	Record	Well, Probe	Unclass- ified
,	w/ and w/o Modifiers	Α	[*] (3) (4d)	AD	(4a)	Element	Giass		_	(4a)	ion	Conn.)	Total		Probe	mea
Α	Analysis	AA[*]		AAD[*]		AE	NA	Al	AL		NA	AP	NA	AR	AW	AX
ΑZ	Analysis(SIS))	AZA[*]	F#1	NA		AZE	NA	AZI	AZL		NA	AZP	NA	AZR	AZW	NA
В	Burner, Combustion	BA[*]	[*] = Alarm	BAD[*]		BE	BG	BI	BL		NA	BP	NA	BR	BW	BX
BZ	Burner, Comb(SIS)	BZA[*]	and other	NA		BZE	NA	BZI	BZL		NA	BZP	NA	BZR	BZW	NA
С	User's Choice		Function													
D	User's Choice		Modifier													
Е	Voltage	EA[[*]]	EAD[*]		EE	EG	El	EL		EO	EP	NA	ER	NA	EX
EZ	Voltage(SIS)	EZA[*]	High-High HH	NA		EZE	NA	EZI	EZL		NA	EZP	NA	EZR	EZW	NA
F	Flow, Flow Rate	FA[*]	High	FAD[*]		FE	FG	FI	FL		FO	FP	FQ	FR	NA	FX
FF	Flow Ratio	FFA[*	H	FFAD[*]		FFE	NA	FFI	NA		NA	NA	NA	FFR	NA	FFX
FQ	Flow Total	FQA[*]	Middle	FQAD[*]		FQE	NA	FQI	NA		NA	NA	NA	FQR	NA	FQX
FS	Flow Safety	NA	М	NA		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
FZ	Flow(SIS)	FZA[*]	Low	NA		FZE	NA	FZI	FZL		NA	FZP	NA	FZR	FZW	NA
G	User's Choice		L Low-Low													
Н	Hand	HA[*]	LL	NA		NA	NA	HI	NA		NA	NA	NA	HR	NA	HX
HZ	Hand(SIS)	HZA[*]		NA		NA	NA	NA	NA		NA	NA	NA	HZR	NA	NA
- 1	Current	IA[*]	Open	IAD[*]		ΙE	IG	II	IL		10	ΙP	NA	IR	NA	IX
ΙZ	Current(SIS)	IZA[*]	0	NA		IZE	NA	IZI	IZL		NA	IZP	NA	BZR	BZW	NA
J	Power	JA[*]	Close C	JAD[*]		JE	JG	JI	JL		JO	JP	JQ	JR	NA	JX
JQ	Power Totalize	JQA[*]		NA		JE	NA	JQI			NA	JP	NA	JQR	NA	JQX
JZ	Power(SIS)	JZA[*]	Run	NA		JZE	NA	JZI	JZL		NA	JZP	NA	JZR	NA	NA
K	Time, Schedule	KA[*]	R	KAD[*]		NA	KG	KI	KL		NA	NA	KQ	KR	NA	KX
KQ	Time Totalize	KQA[*]	Stop	NA		NA	KQG	KQI	KQL		NA	NA	NA	KQR	NA	KQX
L	Level	LA[*]	S	LAD[*]		LE	LG	LI	LL		NA	LP	NA	LR	LW	LX
LZ	Level(SIS)	LZA[*]	Unclassified	NA		LZE	NA	LZI	LZL		NA	LZP	NA	BZR	BZW	NA
М	User's Choice		X													
N	User's Choice] ^													
0	User's Choice								· ·			· ·				

ANSI/ISA-5.1-2009 - 104 -

Table A.3.1.2 — Allowable succeeding letters for readout/passive functions and first letters P to VZZ (1) (4b)

11010.	First Letters (2)	00 10101 10	A	i y notoo ii	В	E	G	I	L	N	0	Р	Q	R	W	Х
	sured/Initiating Variables	Absolute Alarm	Function Modifier	Deviation Alarm	User's Choice (4a)	Primary Element	Gauge, Glass	Indicate	Light	User's Choice (4a)	Orifice, Restrict-	Point (Test Conn.)	Integrate, Total	Record	Well, Probe	Unclass-
		A	[*] (3) (4d)	AD	(4a)	DE	DO (E)	DI.	Di	(4a)	ion		114	- DD	114	DV
Р	Pressure	PA[*]		PAD[*]		PE	PG (5)	PI	PL		NA	PP	NA	PR	NA	PX
PD	Pressure Differential	PDA[*]		PDAD[*]		PDE	PDG (5)	PDI	PDL		NA	NA	NA	PDR	NA	PDX
PF	Pressure Ratio	PFA[*]		PFAD[*]		PE	NA	PFI	NA		NA	NA	NA	PFR	NA	PFX
PJ	Pressure Scan	PJA[*]	[*] =	NA		PE	NA	NA	NA		NA	NA	NA	PJR	NA	NA
PK	Pressure Rate of Change	PKA[*]	Alarm	PKAD[*]		PE	NA	PKI	PKL		NA	NA	NA	PKR	NA	PKX
PS	Pressure Safety	NA	and other	NA		PSE (6)	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
PZ	Pressure(SIS)	PZA[*]	Function	NA		PZE	NA	PZI	PZL		NA	PZP	NA	BZR	BZW	NA
Q	Quantity	QA[*]	Modifier	QAD[*]		QE	NA	QI	QL		NA	NA	QQ	QR	NA	QX
QQ	Quantity Totalize	QQA[*]	Hiab Hiab	NA		QE	NA	QQI	QQL		NA	NA	NA	QQR	NA	QQX
R	Radiation	RA[*]	High-High HH	RAD[*]		RE	RG	RI	RL		NA	RP	RQ	RR	NA	RX
RQ	Radiation Totalize	RQA[*]	High	NA		RE	NA	RQI	RQL		NA	NA	NA	RQR	NA	RQX
RZ	Radiation(SIS)	RZA[*]	Н Н	NA		RZE	NA	RZI	RZL		NA	RZP	NA	BZR	BZW	NA
S	Speed, Frequency	SA[*]	Middle	SAD[*]		SE	SG	SI	SL		NA	SP	NA	SR	NA	SX
SZ	Speed(SIS)	SZA[*]	М	NA		SZE	NA	SZI	SZL		NA	SZP	NA	BZR	BZW	NA
Τ	Temperature	TA[*]	Low	TAD[*]		TE	TG (5)	TI	TL		NA	TP	NA	TR	TW	TX
TD	Temperature Differential	TDA[*]	L Low-Low	TDAD[*]		TDE	TDG (5)	TDI	TDL		NA	NA	NA	TDR	NA	TDX
TF	Temperature Ratio	TFA[*]	LOW-LOW LL	TFAD[*]		TE	NA	TFI	NA		NA	NA	NA	TFR	NA	TFX
TJ	Temperature Scan	TJA[*]]	NA		TJE	NA	TJI	NA		NA	NA	NA	TJR	NA	TJX
TK	Temperature Rate of	TKA[*]	Open	TKAD[*]		TE	NA	TKI	NA		NA	NA	NA	TKR	NA	TKX
TS	Temperature Safety	NA	0	NA		TSE (6)	NA	NA	NA		NA	NA	NA	NA	NA	NA
TZ	Temperature(SIS)	TZA[*]	Close	NA		TZE	NA	TZI	TZL		NA	TZP	NA	TZR	TZW	NA
U	Multivariable	UA[*]	С	NA		NA	NA	UI	NA		NA	NA	NA	UR	NA	UX
UJ	Multivariable Scan	UJA[*]]	Run	NA		NA	NA	UJI	NA		NA	NA	NA	UJR	NA	UJX
UZ	Multivariable(SIS)	UZA[*]	R	NA		UZE	NA	UZI	UZL		NA	UZP	NA	UZR	UZW	NA
V	Vibr., Mach. Analysis	VA[*]	Stop	VAD[*]		VE	VG	VI	VL		NA	VP	NA	VR	NA	VX
VZ	Vibration(SIS)	VZA[*]	S	NA		VZE	NA	VZI	VZL		NA	NA	NA	VZR	NA	NA
VX	Vibration X-Axis	VXA[*]]	VXAD[*]		VXE	VXG	VXI	VXL		NA	VXP	NA	VXR	NA	VXX
VY	Vibration Y-Axis	VYA[*]	Unclassified X	VYAD[*]		VYE	VYG	VYI	VYL		NA	VYP	NA	VYR	NA	VYX
VZ	Vibration Z-Axis	VZA[*]	^	VZAD[*]		VZE	VZG	VZI	VZL		NA	VZP	NA	VZR	NA	VZX
VZX	Vibration X-Axis(SIS)	VZA[*]		NA		VZE	NA	VZI	VZL		NA	VZP	NA	VZR	NA	NA
VZY	Vibration Y-Axis(SIS)	VZA[*]		NA		VZE	NA	VZI	VZL		NA	VZP	NA	VZR	NA	NA
VZZ	Vibration Z-Axis(SIS)	VZA[*]	j	NA		VZE	NA	VZI	VZL		NA	VZP	NA	VZR	NA	NA

- 105 - ANSI/ISA-5.1-2009

Table A.3.1.3 — Allowable succeeding letters for readout/passive functions and first letters W to ZDZ (1) (4b)

Note				ry notes ir										_		
	First Letters (2)				В	E	G	I	L	N	0	P	Q	R	W	Х
		Alarm	Function Modifier [*] (3) (4d)	Deviation Alarm AD	User's Choice (4a)	Primary Element	Gauge, Glass	Indicate	Light	User's Choice (4a)	Orifice, Restrict- ion	Point (Test Conn.)	Integrate, Total	Record	Well, Probe	Unclass- ified
W	Weight Force		[](0)(40)	WAD[*]		WE	WG	WI	WL	` '	NA	NA	NA	WR	NA	WX
WZ	U ,		[*] -	NA NA		WZE	NA NA	NA NA	NA NA		NA NA	NA	NA NA	XR	NA NA	NA
WD	\ /		Alarm	WDADI*1		WE	NA	WDI	WDL		NA NA	NA	NA NA	WDR	NA NA	WDX
WF	J		and other	WFAD[*]		WE	NA	WFI	NA		NA NA	NA	NA NA	WFR	NA NA	WFX
WK			Function	WKAD[*]		WE	NA NA	WKI	WQL		NA NA	NA	NA NA	WKR	NA NA	WKX
WQ	, ,		Modifier	WQAD[*]		WE	NA	WQI	NA		NA	NA	NA	WQR	NA	WQX
WX	U		Lligh Lligh	WXAD[*]		WXE	NA	WXI	WXL		NA	NA	NA	WXR	NA	WXX
WY			HH	WYAD[*]		WYE	NA	WAI	WYL		NA	NA	NA	WAR	NA	WAX
WZ			High	WZAD[*]		WZE	NA	WZI	WZL		NA	NA	NA	WZR	NA	WZX
WZX	Force X Axis(SIS)	WZXA[*]		NA		WZE	NA	WZI	WZXL		NA	WZXP	NA	WZXR	NA	NA
WZY	Force Y Axis(SIS)		Middle	NA		WZE	NA	WZI	WZYL		NA	WZYP	NA	WZYR	NA	NA
WZZ	Force Z Axis(SIS)	WZZA[*]		NA		WZE	NA	WZI	WZZL		NA	WZZP	NA	WZZR	NA	NA
Χ	Unclassified	XA[*]	L	XAD[*]		XE	XG	ΧI	XL		NA	XP	XQ	XR	XW	XX
Υ	Event, State, Presence	YA[*]	Low-Low	NA		YE	NA	ΥI	YL		NA	NA	NA	YR	NA	YX
YZ	Event, State(SIS)	YZA[*]	LL	NA		YZE	NA	YZI	YZL		NA	NA	NA	YZR	NA	YZX
Z	Position, Dimension	ZA[*]	Onon	ZAD[*]		ZE	ZG	ZI	ZL		NA	NA	NA	ZR	NA	ZX
ZZ	Position(SIS)	ZZA[*]	Open O	NA		ZZE	NA	ZZI	ZZL		NA	NA	NA	ZZR	NA	NA
ZX	Position X Axis	ZXA[*]	Close	ZXAD[*]		ZXE	ZXG	ZXI	ZXL		NA	NA	NA	ZXR	NA	ZXX
ZY	Position Y Axis	ZYA[*]	С	ZYAD[*]		ZYE	ZYG	ZYI	ZYL		NA	NA	NA	ZYR	NA	ZYX
ZZ	Position Z Axis	ZZA[*]	_	ZZAD[*]		ZZE	NA	ZZI	ZZL		NA	NA	NA	ZZR	NA	ZZX
ZZX	Position X Axis(SIS)	ZZXA[*]	Run R	NA		ZZXE	NA	ZZXI	ZZXL		NA	ZZXP	NA	ZZXR	NA	NA
ZZY	Position Y Axis(SIS)	ZZYA[*]	Stop	NA		ZZYE	NA	ZZYI	ZZYL		NA	ZZYP	NA	ZZYR	NA	NA
ZZZ	Position Z Axis(SIS)	ZZZA[*]	S	NA		ZZZE	NA	ZZZI	ZZZL		NA	ZZZP	NA	ZZZR	NA	NA
ZD	Position Difference	ZDA[*]]	ZDAD[*]		ZDE	ZDG	ZDI	ZDL		NA	NA	NA	ZDR	NA	ZDX
ZDX	Position Difference X Axis	ZDXA[*]	Unclassified	ZDXAD[*]		ZDXE	ZDXG	ZDXI	ZDXL		NA	NA	NA	ZDXR	NA	ZDXX
ZDY	Position Difference Y Axis	ZDYA[*]	X	ZDYAD[*]		ZDYE	ZDYG	ZDYI	ZDYL		NA	NA	NA	ZDYR	NA	ZDYX
ZDZ	Position Difference Z Axis	ZDZA[*]		ZDZAD[*]		ZDZE	ZDZG	ZDZI	ZDZL		NA	NA	NA	ZDZR	NA	ZDZX

ANSI/ISA-5.1-2009 - 106 -

Table A.3.2.1 — Allowable succeeding letters for output/active function letters and first letters A to O (1) (4b2)

Note: Numbers in parentheses refer to explanatory notes in A.16.3. First Letters B C K N S T																1	1	
	First Letters	В		(<u> </u>		K	N		·		T		U	V	Х	Y	Z
Mea	sured/Initiating Variables w/ and w/o Modifiers	User's Choice	Control	Indicate Control	Record Control	Control Valve	Control Station	User's Choice	Switch	Function Modifier	Transmit	Transmit	Recording Transmit	Multi- function	Valve Damper	Unclass- ified	Compute, Convert	Actuator, Drive
	w/ and w/o wodiners	(4a)	C (7)	IC (8)	RC (8)	CV (9)		(4a)	S	[*] (3) (4d)	T	IT	RT		Louver		Relay	
Α	Analysis		AC	AIC	ARC	NA	AK		AS[*]		AT	AIT	ART	AU	AV	AX	AY	AZ
ΑZ	Analysis(SIS))		AZC	AZIC	AZRC	NA	NA		AZS[*]		AST	NA	NA	AZU	AZV	NA	AZY	AZZ
В	Burner, Combustion		BC	BIC	BRC	NA	BK		BS[*]	[*] =	BT	BIT	BRT	BU	BV	BX	BY	BZ
BZ	Burner, Comb.(SIS)		BZC	BZIC	BZRC	NA	NA		BZS[*]	Function	BZT	NA	NA	BZU	BZV	NA	BZY	BZZ
С	User's Choice									Modifier								
D	User's Choice																	
Е	Voltage		EC	EIC	ERC	NA	EK		ES[*]	High-High	ET	EIT	ERT	EU	NA	EX	EY	EZ
EZ	Voltage(SIS)		EZC	EZIC	EZRC	NA	NA		EZS[*]	HH	EZT	NA	NA	EZU	NA	EZX	EZY	EZZ
F	Flow, Flow Rate		FC	FIC	FRC	FCV	FK		FS[*]	High H	FT	FIT	FRT	FU	FV	FX	FY	NA
FF	Flow Ratio		FFC	FFIC	FFRC	NA	FFK		FFS[*]	Middle	FFT	FFIT	FFRT	FFU	FFV	FFX	FFY	NA
FQ	Flow Total		FQC	FQIC	FQRC	FQCV	FQK		FQS[*]	М	FQT	FQIT	FQRT	FQU	FQV	FQX	FQY	NA
FS	Flow Safety		NA	NA	NA	FSV	NA		NA	Low	NA	NA	NA	NA	FSV (10)	NA	NA	NA
FZ	Flow(SIS)		FZC	FZIC	FZRC	NA	NA		FZS[*]	. L	FZT	NA	NA	FZU	FZV	NA	FZY	NA
G	User's Choice									Low-Low LL								
Н	Hand		HC	HIC	HRC	HCV	NA		HS	LL	NA	NA	NA	HU	HV	HX	HY	HZ
HZ	Hand(SIS)		HZC	HZIC	HZRC	NA	NA		HZS	Open	NA	NA	NA	HZU	HZV	NA	HZY	HZZ
1	Current		IC	IIC	IRC	NA	IK		IS[*]	O	IT	IIT	IRT	IU	NA	IX	ΙΥ	ΙZ
ΙZ	Current(SIS)		IZC	IZIC	IZRC	NA	NA		IZS[*]	Close	IZT	NA	NA	IZU	NA	IZX	IZY	IZZ
J	Power		JC	JIC	JRC	NA	JK		JS[*]	С	JT	JIT	JRT	JU	NA	JX	JY	JZ
JQ	Power Totalize		JQC	JQIC	JQRC	NA	JQK		JQS[*]	Run	JQT	JQIT	JQRT	JQU	NA	JQX	JQY	JQZ
JZ	Power(SIS)		JZC	JZIC	JZRC	NA	NA		JZS[*]	R	JZT	NA	NA	JZU	NA	JZX	JZY	JZZ
K	Time, Schedule		KC	KIC	KRC	NA	KK		KS[*]	Stop	NA	NA	NA	KU	NA	KX	KY	KZ
KQ	Time Totalize		KQC	KQIC	KQRC	NA	NA		KQS	S	NA	NA	NA	KQU	KQV	KQX	KQY	KZZ
L	Level		LC	LIC	LRC	LCV	LK		LS[*]		LT	LIT	LRT	LU	LV	LX	LY	LZ
LZ	Level(SIS)		LZC	LZIC	LZRC	NA	NA		LZS[*]	Unclassified	LZT	NA	NA	LZU	LZV	LZX	LZY	LZZ
M	User's Choice									Х								
N	User's Choice																	
0	User's Choice																	

- 107 - ANSI/ISA-5.1-2009

Table A.3.2.2 — Allowable succeeding letters for output/active function letters and first letters P to VZZ (1) (4b2)

			ı		•		1/	NI NI		•	l			11	V	v	٧	7
	First Letters	В.			<u> </u>		K	N		S Function		<u>l</u>		U	V	Х		Z
	sured/Initiating Variables	User's Choice	Control	Indicate Control	Record Control	Control Valve	Control Station	User's Choice	Switch	Modifier	Transmit	Transmit	Recording Transmit	Multi- function	Valve Damper	Unclass- ified	Compute, Convert	Actuator, Drive
	w/ and w/o Modifiers	(4a)	C (7)	IC (8)	RC (8)	CV (9)		4a)	S	[*] (3) (4d)	T	IT	RT		Louver		Relay	
Р	Pressure		PC	PIC	PRC	PCV (11)	PK		PS[*]		PT	PIT	PRT	PU	PV	PX	PY	PZ
PD	Pressure Differential		PDC	PDIC	PDRC	PDCV	PDK		PDS[*]		PDT	PDIT	PDRT	PDU	PDV	PDX	PDY	PDZ
PF	Pressure Ratio		PFC	PFIC	PFRC	NA	PFK		PFS[*]		NA	NA	NA	PFU	PFV	PFX	PFY	PFZ
PJ	Pressure Scan		NA	NA	NA	NA	NA		PJS[*]		PJT	NA	NA	NA	NA	NA	NA	NA
PK	Pressure Rate of Change		PKC	PKIC	PKRC	NA	PKK		PKS[*]	[*] =	NA	NA	NA	PKU	PKV	PKX	PKY	PKZ
PS	Pressure Safety		NA	NA	NA	PSV	NA		NA	Function	NA	NA	NA	NA	PSV (9)	NA	NA	NA
PZ	Pressure(SIS)		PZC	PZIC	PZRC	NA	NA		PZS[*]	Modifier	PZT	NA	NA	PZU	PZV	PZX	PZY	PZZ
Q	Quantity		QC	QIC	QRC	NA	QK		QS[*]		QT	QIT	NA	QU	QV	QX	QY	QZ
QQ	Quantity Totalize		QQC	QQIC	QQRC	NA	QQK		QQS[*]	High-High	QQT	QQIT	NA	QQU	QQV	QQX	QQY	QQZ
R	Radiation		RC	RIC	RRC	NA	RK		RS[*]	HH	RT	RIT	RRT	RU	RV	RX	RY	RZ
RQ	Radiation Totalize		RQC	RQIC	RQRC	NA	RQK		RQS[*]	High H	RQT	NA	NA	RQU	RQV	RQX	RQY	RQZ
RZ	Radiation(SIS)		RZC	RZIC	RZRC	NA	NA		RZS[*]	Middle	RZT	NA	NA	RZU	RZV	RZX	RZY	RZZ
S	Speed, Frequency		SC	SIC	SRC	SCV	SK		SS[*]	М	ST	SIT	SRT	SU	SV	SX	SY	SZ
SZ	Speed(SIS)		SZC	SZIC	SZRC	SZCV	NA		SZS[*]	Low	SZT	NA	NA	SZU	SZV	SZX	SZY	SZZ
T	Temperature		TC	TIC	TRC	TCV	TK		TS[*]]	L	TT	TIT	TRT	TU	TV	TX	TY	TZ
TD	Temperature Differential		TDC	TDIC	TDRC	NA	TDK		TDS[*]	Low-Low	TDT	TDIT	TDRT	TDU	TDV	TDX	TDY	TDZ
TF	Temperature Ratio		TFC	TFIC	TFRC	NA	TFK		TFS[*]	LL	NA	NA	NA	TFU	TFV	TFX	TFY	TFZ
TJ	Temperature Scan		NA	NA	NA	NA	NA		TJS[*]	Open	TJT	NA	NA	NA	NA	NA	NA	NA
TK	Temperature Rate of Change		TKC	TKIC	TKRC	NA	TKK		TKS[*]	0	NA	NA	NA	TKU	TKV	TKX	TKY	TKZ
TS	Temperature Safety		NA	NA	NA	TSV	NA		NA	Close	NA	NA	NA	NA	TSV (9)	NA	NA	NA
TZ	Temperature(SIS)		TZC	TZIC	TZRC	NA	NA		TZS[*]	С	TZT	NA	NA	TZU	TZZV	TZX	TZY	TZZ
U	Multivariable		UC	UIC	URC	NA	NA		US[*]	Run	NA	NA	NA	UU	UV	UX	UY	UZ
UJ	Multivariable Scan		NA	NA	NA	NA	NA		NA	R	NA	NA	NA	NA	NA	NA	NA	NA
UZ	Multivariable(SIS)		UZC	UZIC	UZRC	NA	NA		UZS[*]	Stop	NA	NA	NA	UZU	UZV	UZX	UZY	UZZ
V	Vibr., Mach. Analysis		VC	VIC	VRC	NA	VK		VS[*]	s	VT	VIT	VRT	VU	NA	VX	VY	NA
VZ	Vibration(SIS)		VZC	VZIC	VZRC	NA	NA		VZS[*]		VZT	NA	NA	VZZU	NA	VZX	VZY	NA
VX	Vibration X-Axis		VXC	VXIC	VXRC	NA	NA		VXS[*]	Unclassified	VXT	VXIT	VXRT	VXU	NA	VXX	VXY	NA
VY	Vibration Y-Axis		VYC	VYIC	VYRC	NA	NA		VYS[*]	X	VYT	VYIT	VYRT	VYU	NA	VYX	VYY	NA
VZ	Vibration Z-Axis		VZC	VZIC	VZRC	NA	NA		VZS[*]	1	VZT	VZIT	VZRT	VZU	NA	VZX	VZY	NA
VZX	Vibration X-Axis(SIS)		VZXC	VZXIC	VZXRC	NA	NA		VZXS[*]	1	VZXT	NA	NA	VZXU	NA	VZXX	VZXY	NA
VZY	Vibration Y-Axis(SIS)		VZYC	VZYIC	VZYRC	NA	NA		VZYS[*]	1	VZYT	NA	NA	VZYU	NA	VZYX	VZYY	NA
VZZ	Vibration Z-Axis(SIS)		VZZC	VZZIC	VZZRC	NA	NA		VZZS[*]	1	VZZT	NA	NA	VZZU	NA	VZZX	VZZY	NA

ANSI/ISA-5.1-2009 - 108 -


Table A.3.2.3 — Allowable succeeding letters for output/active function letters and first letters W to ZDZ (1) (4b2)

First Letters		В	' '					N		S	Т			U	V	Х	Υ	Z
Measured/Initiating Variables w/ and w/o Modifiers		User's Choice (4a)	Control	Indicate Control IC (8)	Record Control RC (8)	Control Valve CV (9)	Control Station	User's Choice (4a)	Switch	Function Modifier [*] (3) (4d)	Transmit		Recording Transmit RT	Multi- function	Valve Damper Louver	Unclass- ified	Compute, Convert Relay	Actuator, Drive
W	Weight, Force	, ,	WC	WIC	WRC	WCV	WK	, ,	WS[*]	[](0)(10)	WT	WIT	WR	WU	WV	WX	WY	WZ
WZ	Force(SIS)		WZC	WZIC	WZRC	NA	NA		WZS[*]		WZT	NA	N	WZU	WZV	WZX	WZY	WZZ
WD	Weight Differential		WDC	WDIC	WDRC	NA	WDK		WDS[*]	[*] =	WDT	WDIT	WDRT	WDU	WDV	WDX	WDY	WDZ
WF	Weight Ratio		WFC	WFIC	WFRC	NA	WFK		WFS[*]	Function	NA	NA	NA	WFU	WFV	WFX	WFY	NA
WK	Weight Loss (Gain)		WKC	WKIC	WKRC	NA	WKK		WKS[*]	Modifier	WKT	WKIT	WKRT	WKU	WKV	WKX	WKY	WKZ
WQ	Weight Total		WQC	WQIC	WQRC	NA	WQK		WQS[*]	High-High	NA	NA	NA	WQU	WQV	WQX	WQY	WQZ
WX	Force X Axis		WXC	WXIC	WXRC	NA	WXK		WXS[*]	HH	WXT	WXIT	WXRT	WXU	WXV	WXX	WXY	WXZ
WY	Force Y Axis		WYC	WYIC	WYRC	NA	WYK		WYS[*]	High	WYT	WYIT	WYRT	WYU	WYV	WYX	WYY	WYZ
WZ	Force Z Axis		WZC	WZIC	WZRC	NA	WZK		WZS[*]	H	WZT	WZIT	WZRT	WZU	WZV	WZX	WZY	WZZ
WZX	Force X Axis(SIS)		WZXC	WZXIC	WZXRC	NA	NA		WZXS[*]	Middle	WZXT	NA	NA	WZXU	WZXV	WZXX	WZXY	WZXZ
WZY	Force Y Axis(SIS)		WZYC	WZYIC	WZYRC	NA	NA		WZYS[*]	M Low	WZYT	NA	NA	WZYU	WZYV	WZYX	WZYY	WZYZ
WZZ	Force Z Axis(SIS)		WZZC	WZZIC	WZZRC	NA	NA		WZZS[*]	L	WZZT	NA	NA	WZZU	WZZV	WZZX	WZZY	WZZZ
Χ	Unclassified		XC	XIC	XRC	NA	XK		XS[*]	Low-Low	XT	XIT	XRT	XU	XV	XX	XY	XZ
Υ	Event, State, Presence		YC	YIC	YRC	NA	YK		YS[*]	LL	YT	YIT	YRT	YU	YV	YX	YY	YZ
YZ	Event, State(SIS)		YZC	YZIC	YZRC	NA	NA		YZS[*]	0	YZT	NA	NA	YZU	YZV	YZX	YZY	YZZ
Z	Position, Dimension		ZC	ZIC	ZRC	NA	ZK		ZS[*]	Open O	ZT	ZIT	ZRT	ZU	ZV	ZX	ZY	ZZ
ZZ	Position(SIS)		ZZC	ZZIC	ZZRC	NA	NA		ZZS[*]	Close	ZZT	NA	NA	ZZU	ZZV	ZZX	ZZY	ZZZ
ZX	Position X Axis		ZXC	ZXIC	ZXRC	NA	ZXK		ZXS[*]	С	ZXT	ZXIT	ZXRT	ZXU	ZXV	ZXX	ZXY	ZXZ
ZY	Position Y Axis		ZYC	ZYIC	ZYRC	NA	ZYK		ZYS[*]		ZYT	ZYIT	ZYRT	ZYU	ZYV	ZYX	ZYY	ZYZ
ZZ	Position Z Axis		ZZC	ZZIC	ZZRC	NA	NA		ZZS[*]	Run	ZZT	NA	NA	ZZU	ZZV	ZZX	ZZY	ZZZ
ZZX	Position X Axis(SIS)		ZZXC	ZZXIC	ZZXRC	NA	NA		ZZXS[*]	R Stop	ZZXT	NA	NA	ZZXU	ZZXV	ZZXX	ZZXY	ZZXZ
ZZY	Position Y Axis(SIS)		ZZYC	ZZYIC	ZZYRC	NA	NA		ZZYS[*]	Stop	ZZYT	NA	NA	ZZYU	ZZYV	ZZYX	ZZYY	ZZYZ
ZZZ	Position Z Axis(SIS)		ZZZC	ZZZIC	ZZZRC	NA	NA		ZZZS[*]	Ŭ	ZZZT	NA	NA	ZZZU	ZZZV	ZZZX	ZZZY	ZZZZ
ZD	Position Difference		ZDC	ZDIC	ZDRC	NA	ZDK		ZDS[*]	Unclassified	ZDT	ZDIT	ZDRT	ZDU	ZDV	ZDX	ZDY	ZDZ
ZDX	Position Diff. X Axis		ZDXC	ZDXIC	ZDXRC	NA	ZDXK		ZDXS[*]	Х	ZDXT	ZDXIT	ZDXRT	ZDXU	ZDXV	ZDXX	ZDXY	ZDXZ
ZDY	Position Diff. Y Axis		ZDYC	ZDYIC	ZDYRC	NA	ZDYK		ZDYS[*]		ZDYT	ZDYIT	ZDYRT	ZDYU	ZDYV	ZDYX	ZDYY	ZDYZ
ZDZ	Position Diff. Z Axis		ZDZC	ZDZIC	ZDZRC	NA	ZDZK		ZDZS[*]		ZDZT	ZDZIT	ZDZRT	ZDZU	ZDZV	ZDZX	ZDZY	ZDZZ

Table A.4 — Loop and Identification Tag Number suffixes (1) (2)

Note: Numbers in parentheses refer to explanatory notes in Clause A.16.4.

First ₋oop Suffix		Loop Identification Number Suffixes(Bold-Italic)		Identification/Tag Number suffixes (Bold-Underlined)						
			Case 1 — Different services (3)							
	After loop numbers	After first letters	Two devices with loop suffix after			Four devices with loop suffix after				
	numbers		None	Numbers	Letters	None	Numbers	Letters		
			FV*01- 1			FV*01- <u>1A</u>				
None	F*01		FV 01- <u>1</u>			FV*01- <u>1B</u>				
			FV*01- 2			FV*01- <u>2A</u>				
						FV*01- <u>2B</u>				
		F- <i>A</i> -*01		FV*01 <i>A</i> - 1	FV- <i>A</i> -*01- 1		FV*01 <i>A</i> - <u>1A</u>	FV- <i>A</i> -*01- <u>1/</u>		
				_	_		FV*01 <i>A</i> - <u>1B</u>	FV- <i>A</i> -*01- <u>1</u> 1		
				FV*01 <i>A</i> - <u>2</u>	FV- <i>A</i> -*01- <u>2</u>		FV*01 <i>A</i> - 2A	FV-A-*01- <u>2</u>		
Alpha	F*01 <i>A</i>				<u> </u>		FV*01 <i>A</i> -2B	FV-A-*01- <u>2</u>		
-				FV*01 <i>B</i> - <u>1</u>	FV- <i>B</i> -*01- <u>1</u>		FV*01 <i>B</i> - 1A	FV- <i>B</i> -*01- <u>1/</u>		
							FV*01 <i>B</i> - <u>1B</u>	FV- <i>B</i> -*01- <u>11</u>		
				FV*01 <i>B</i> - <u>2</u>	FV- <i>B</i> -*01- <u>2</u>		FV*01 <i>B</i> - 2A FV*01 <i>B</i> - 2B	FV- <i>B</i> -*01- <u>2</u>		
				+			FV*01 <i>B</i> - <u>2B</u> FV*01- <i>1</i> -1A	FV- <i>B</i> -*01- <u>2</u> 1		
Numeric	F*01- <i>1</i>	F- <i>1</i> -*01		FV*01- <i>1</i> - <u>1</u>	FV- <i>1</i> -*01- <u>1</u>			FV- <i>1</i> -*01- <u>1/</u>		
							FV*01- <i>1</i> - <u>1B</u>	FV- <i>1</i> -*01- <u>11</u>		
				FV*01- <i>1</i> - <u>2</u>	FV- <i>1</i> -*01- <u>2</u>		FV*01- <i>1</i> - <u>2A</u> FV*01- <i>1</i> - <u>2B</u>	FV- <i>1</i> -*01- <u>2</u> FV- <i>1</i> -*01- 2 l		
							FV*01- <i>1</i> - <u>2B</u> FV*01- <i>2</i> - <u>1A</u>	FV- <i>1</i> - 01- <u>21</u> FV- <i>2</i> -*01- 1		
				FV*01- <i>2</i> - <u>1</u>	FV- <i>2</i> -*01- <u>1</u>		FV*01-2- <u>1A</u>	FV-2-*01- <u>11</u>		
							FV*01-2- <u>1B</u>	FV-2-*01- 2		
				FV*01- <i>2</i> - <u>2</u>	FV- <i>2</i> -*01 -2		FV*01-2-2B	FV-2-*01- <u>21</u>		
			Case 2 — Same service (3)					1 7 2 01 21		
			Two devi	vo devices with loop suffix after		Four devices with loop suffix after				
			None	Numbers	Letters	None	Numbers	Letters		
None				11011110110		FV*01- A1	110			
			FV*01- <u>A</u>			FV*01- <u>B1</u>				
			E) #04 B	1	ĺ	FV*01- A2				
			FV*01- <u>B</u>		ĺ	FV*01- B2				
				E\/*01.4. A	E\/ 4 *01 A		FV*01 <i>A</i> - <u>A1</u>	FV- <i>A</i> -*01- <u>A</u>		
				FV 01A- <u>A</u>	FV-A- 01- <u>A</u>		FV*01 <i>A</i> - <u>A2</u>	FV- <i>A</i> -*01- <u>A</u>		
		l l		E\/*01./LB	E\/_/L*01_ B		FV*01 <i>A</i> - <u>B1</u>	FV- <i>A</i> -*01- <u>B</u>		
				1 V 0174- <u>D</u>	1 V-71- V 1- <u>D</u>		FV*01 <i>A</i> - B2	FV- <i>A</i> -*01- <u>B</u>		
Δlnha										
Alpha				FV*01 <i>B</i> - A	FV- <i>R</i> -*01- A		FV*01 <i>B</i> - <u>A1</u>	FV- <i>B</i> -*01- <u>A</u>		
Alpha				FV*01 <i>B</i> - <u>A</u>	FV- <i>B</i> -*01- <u>A</u>		FV*01 <i>B</i> - <u>A1</u> FV*01 <i>B</i> - <u>A2</u>	FV- <i>B</i> -*01- <u>A</u>		
Alpha				_	_		FV*01 <i>B</i> - <u>A2</u> FV*01 <i>B</i> - <u>B1</u>	FV- <i>B</i> -*01- <u>A</u> FV- <i>B</i> -*01- <u>B</u>		
Alpha				FV*01 <i>B</i> - <u>A</u> FV*01 <i>B</i> - <u>B</u>	FV- <i>B</i> -*01- <u>A</u> FV- <i>B</i> -*01- <u>B</u>		FV*01 <i>B</i> - <u>A2</u> FV*01 <i>B</i> - <u>B1</u> FV*01 <i>B</i> - <u>B2</u>	FV- <i>B</i> -*01- <u>A</u> FV- <i>B</i> -*01- <u>B</u> FV- <i>B</i> -*01- <u>B</u>		
Alpha				FV*01 <i>B</i> - <u>B</u>	FV- <i>B</i> -*01- <u>B</u>		FV*01 <i>B</i> - <u>A2</u> FV*01 <i>B</i> - <u>B1</u> FV*01 <i>B</i> - <u>B2</u> FV*01-1- <u>A1</u>	FV- <i>B</i> -*01- <u>A</u> FV- <i>B</i> -*01- <u>B</u> FV- <i>B</i> -*01- <u>B</u> FV- <i>1</i> -*01- <u>A</u>		
Alpha				_	_		FV*01 <i>B</i> - <u>A2</u> FV*01 <i>B</i> - <u>B1</u> FV*01 <i>B</i> - <u>B2</u> FV*01-1- <u>A1</u> FV*01-1- <u>A2</u>	FV- <i>B</i> -*01- A FV- <i>B</i> -*01- B FV- <i>I</i> -*01- A FV-1-*01- A		
Alpha				FV*01 <i>B</i> · <u>B</u> FV*01- <i>1</i> - <u>A</u>	FV- <i>B</i> -*01- <u>B</u> FV- <i>1</i> -*01- <u>A</u>		FV*01 <i>B</i> - <u>A2</u> FV*01 <i>B</i> - <u>B1</u> FV*01 <i>B</i> - <u>B2</u> FV*01-1- <u>A1</u> FV*01-1- <u>A2</u> FV*01-1- <u>B1</u>	FV- <i>B</i> -*01- <u>A</u> FV- <i>B</i> -*01-B FV- <i>B</i> -*01-B FV-1-*01-A FV-1-*01-A		
Alpha Numeric				FV*01 <i>B</i> - <u>B</u>	FV- <i>B</i> -*01- <u>B</u>		FV*01 <i>B</i> - <u>A2</u> FV*01 <i>B</i> - <u>B1</u> FV*01 <i>B</i> - <u>B2</u> FV*01-1- <u>A1</u> FV*01-1- <u>B1</u> FV*01-1- <u>B1</u>	FV-B-*01-A FV-B-*01-B FV-B-*01-B FV-1-*01-A FV-1-*01-B FV-1-*01-B		
				FV*01 <i>B</i> · <u>B</u> FV*01- <i>1</i> - <u>A</u>	FV- <i>B</i> -*01- <u>B</u> FV- <i>1</i> -*01- <u>A</u>		FV*01 <i>B</i> - <u>A2</u> FV*01 <i>B</i> - <u>B1</u> FV*01 <i>B</i> - <u>B2</u> FV*01-7- <u>A1</u> FV*01-7- <u>A2</u> FV*01-7- <u>B1</u> FV*01-7- <u>B2</u> FV*01-2- <u>A1</u>	FV-B*01- <u>A</u> FV-B*01- <u>B</u> FV-B*01-B FV-1*01-A FV-1*01-B FV-1*01-B FV-2*01-A		
				FV*01 <i>B</i> · <u>B</u> FV*01- <i>1</i> - <u>A</u> FV*01- <i>1</i> -B	FV- <i>B</i> -*01- <u>B</u> FV- <i>1</i> -*01- <u>B</u> FV- <i>1</i> -*01- <u>B</u>		FV*01 <i>B</i> - <u>A2</u> FV*01 <i>B</i> - <u>B1</u> FV*01 <i>B</i> - <u>B2</u> FV*01-1- <u>A1</u> FV*01-1- <u>B1</u> FV*01-1- <u>B1</u>	FV-B*01-A FV-B*01-B FV-B*01-B FV-1*01-A FV-1*01-A FV-1*01-B FV-1*01-B FV-2*01-A FV-2*01-B		
None			FV*01- <u>B</u>	FV*01 <i>A</i> - <u>A</u> FV*01 <i>A</i> - <u>B</u>	FV- <i>A</i> -*01- <u>A</u> FV- <i>A</i> -*01- <u>B</u>		FV*01 <i>A</i> - <u>A</u> FV*01 <i>A</i> - <u>E</u>	A2 B1		



Annex B Graphic symbol guidelines (informative annex)


- B.1 Graphic symbols
- B.1.1 This informative annex to the standard describes the use of graphic symbols that are used to depict instrument loop devices and functions, application software functions, and the interconnections between them that is logical, unique, and consistent in application with a minimum of exceptions, special uses, or requirements.
- B.1.2 Graphic symbols, when used with identification letters and numbers constructed as described in Annex A, should as a minimum describe the functionality of, and if assigned a loop number provide a unique identity for, each device and function shown.
- B.2 Instrument identification applied to graphic symbols
- B.2.1 Instrument identification applied to graphic symbols should include, as a minimum, an alphabetic functional identification to identify the functionality of devices and functions shown in the diagrams as described in Annex A.
- B.2.2 Tables A.3.1.1 through A.3.6.2 provide examples of allowable functional identifications.
- B.2.3 Brief explanatory notes or other text may be added adjacent to a symbol or in the note section of a drawing or sketch to clarify the meaning or purpose of a device or function.
- B.2.4 Loop Identification Number numerals, when assigned in accordance with A.6, complete the identity of the loop being shown.
- B.2.5 Lettering fonts should be similar to Arial Narrow and be a minimum of 3/32in(1.125mm) high and a maximum of 13 characters per inch wide.
- B.2.6 A Loop Number prefix should:
 - a) Not be used with bubbles on drawings but indicated in the note section.
 - b) Be used with bubbles if more than one prefix is being used.
 - c) Be used in text.
- B.3 Examples of graphic symbols with assigned instrument/tag numbers
- B.3.1 Instrument bubble symbols should use the upper half of each symbol for Functional Identification Letters and the lower half of each symbol for Loop Numbers:
 - a) Five (5) characters or less:



b) Six (6) characters or more, relieve sides of bubble or enlarge bubble as required:




B.3.2 Functional diagramming, binary logic, and electrical schematic symbols should be tagged at either (A), (B), (C), or (D):




- B.4 Graphic symbol applications
- B.4.1 Graphic symbols provide representations of the instrumentation and functions required for process, machine, or equipment measurement, indication, control, modulation, and switching of variables by any or all of the following applications:
 - a) Instrument diagrams
 - b) Functional diagrams
 - c) Binary logic diagrams
 - d) Electrical schematics
- B.4.2 The most common uses for:
 - a) Instrument diagrams are process flow diagrams (PFDs), piping and instrumentation diagrams (P&IDs), engineering flow diagrams (EFDs), and mechanical flow diagrams (MFDs).
 - b) Functional diagrams are instrument loop device and function details and application software details for microprocessor-based control and monitoring systems.
 - c) Binary logic diagrams are complex, interlocking, and stepwise logic programming and application software for microprocessor-based binary logic systems.
 - d) Electrical schematics are electrical diagrams for motor and other on-off control.
- B.4.3 All of the applications may be used to prepare sketches and drawings for books, magazines, journals, and instruction and maintenance manuals.

- B.5 Device and function symbols
- B.5.1 Instrumentation devices and functions are constructed for sketches, drawings, and diagrams by the use of the generic bubble and other geometric symbols and specific graphic symbols found in Clause 5.
- B.5.2 It is not necessary to show a symbol or a bubble for every device or function required by a loop if the need for the device or function or its tag number is clearly understood; for example:
 - a) Symbols are not required, but may be used, for control valve positioners and stream sample conditioner components.
 - b) Bubbles are not required, but may be used, for orifice plate, thermocouple, and control valve graphic symbols.
- B.5.3 When "smart" drawings, such as computer-generated P&IDs, that are linked to instrument indexes or data sheets are used, a bubble or graphic symbol to which an instrument tag number is attached should be used for all devices and functions that are to be indexed or require data sheets.
- B.6 Instrument diagram and functional diagram example
- B.6.1 Process Flow Diagrams (PFDs) are developed by process engineers to provide basic process data and to describe process operation. Simple instrument diagrams are used to indicate the primary process control measurements and controlled streams required to operate the process. Process monitoring and alarm points and secondary and auxiliary controls and monitors are not shown but are added during the detailed process design and P&ID development.
- B.6.2 A simple flow control requirement should be shown on a PFD as:




- a) Instrument tag numbers should not be assigned on PFDs.
- B.6.3 A typical instrument diagram developed from the PFD diagram:



- a) Bubbles [FE-*01] and [FY-01-B] are optional and not recommended.
- b) Bubble [FV-*01] is optional but is recommended.


B.6.4 Typical equipment and function-oriented functional diagrams developed from the PFD diagram:



B.7 Process variable measurements

- B.7.1 Process variable measurement devices are inserted in or mounted on pipelines and equipment to measure a physical property or to analyze a chemical composition, and include but are not limited to:
 - a) Primary elements, such as orifice plates and thermocouples, that generate analog signals, position mechanical devices, or are used by transmitters to generate signals compatible with the control system.
 - b) Transmitters with integral primary elements, such as vortex shedding flowmeters and filled-capillary temperature devices that generate signals compatible with the control system.
- B.7.2 Process measurements are indicated by:
 - a) Bubbles as shown in Table 5.2.1 for:
 - 1) Generic primary elements.
 - 2) Primary elements that do not have a graphic symbol in Table 5.2.3.
 - 3) Users who elect not to use graphic symbols from Table 5.2.3.
 - b) Graphic symbols from Table 5.3.2.
- B.7.3 Analyzer primary element located in a process slip stream or in a process stream or equipment with or without accessory devices, such as sample conditioners that contain components that are not normally shown, and with type of analyzer and component of interest noted at (**) and (***) respectively:


a) With sample conditioners:



b) Without sample conditioners:




c) Analyzer primary element or transmitter inserted in process stream or equipment:



- B.7.4 Orifice plate primary elements, with or without optional flow arrow, use generic orifice plate symbol with transmitter bubble connected to indicate orifice tap location for flange taps, corner taps, pipe taps, and vena contracta taps respectively:
 - a) Single process connection: corner taps, pipe taps, and vena contracta taps are indicated by notation:




b) Double process connection, pipe taps and vena contracta taps are indicated by notation:




B.7.5 Process root block valves should be shown as required by the piping engineering group.


B.7.6 Orifice meter tubes or runs that are specified and requisitioned by the instrument group should be shown on drawings and sketches by:



- B.8 Final control elements
- B.8.1 Final control elements installed in pipelines and equipment modulate or manipulate the process stream or equipment to affect the loop measured variable.
- B.8.2 Final control elements include, but are not limited to, control valves, solenoid valves, louvers, dampers, motors, variable speed drives, and machine components.
- B.8.3 Control valves are generally pneumatically operated and furnished with positioners that may:
 - a) Be actuated by a pneumatic or an electronic signal.
 - b) Not be shown if all control valves are furnished with positioners.
- B.8.4 Control valves with pneumatic or electronic signal:




b) With positioner:




1) Cross-hatches from positioner to actuator are optional.

c) With tripping solenoid, with and without positioner:




B.8.5 Instrumentation with integral components that:


a) Measure process variables and transmit control and other functions as an integral part of a transmitter:



b) Manipulates control valves as an integral part of a control valve positioner:




c) Is an integral assembly that contains a transmitter, a controller, and a control valve:




B.9 Common instrument-to-instrument signal connections


B.9.1 Pneumatic discrete instrumentation:




B.9.2 Electronic discrete instrumentation:




B.9.3 Shared display, shared control instrumentation:




B.9.4 Shared display, shared control instrumentation, with diagnostic and calibration bus on field wiring:




B.9.5 Shared display, shared control and wireless instrumentation:




B.9.6 Shared display, shared control instrumentation, primary and alternate systems, no inter-bus communication:




B.9.7 Shared display, shared control, primary and alternate systems, with inter-bus communication:




- B.9.8 Shared display, shared control and fieldbus instrumentation, inter-bus communication:
 - a) Fieldbus transmitter/controller and electronic valve positioner:




b) Fieldbus valve positioner/controller and electronic transmitter:




c) Fieldbus transmitter and valve positioner/controller:



B.9.9 Fieldbus valve positioner/controller, transmitter, and indicator:



B.9.10 Fieldbus integral transmitter, controller, and valve positioner:




- B.9.11 Instrument and functional diagrams should not be used to specifically identify signal tubing, wiring, and bus construction methods used to implement a monitoring and control system.
- B.10 Function block symbols
- B.10.1 Signal processing functions should be identified by a function block symbol from Table 7.6 that is:
 - a) Appended to a bubble if an Instrument/Tag Number is required:




b) Attached tangentially to the affected bubble and in line with the signal if the function is an integral part of the affected bubble:




- B.10.2 An example of a common application is the calculation of mass flow with an orifice plate primary element:
 - a) Separate devices or functions that require separate bubbles and tag numbers:




b) Separate devices or application software functions that do not require separate bubbles or tag numbers for each function:




c) Integral devices or application software functions that do not require separate bubbles or tag numbers for each function:




- B.11 Alarm indicators
- B.11.1 Shared control and monitor functions generally allow the indication of four configurable alarms for process variables and setpoint deviations.
- B.11.2 Only alarms that are to be configured are shown.
- B.11.3 Instrument diagramming:
 - a) Process variable alarms:



b) Process variable deviation from setpoint alarms:




c) Process variable deviation from setpoint and process variable alarms:




B.11.4 Functional diagramming:


a) Process variable alarms:



b) Process variable deviation from setpoint alarms:




c) Process variable deviation from setpoint and process variable alarms:




- B.12 Multipoint, multivariable and multifunction instruments
- B.12.1 Multipoint instruments are single or multivariable indicators or recorders that receive input signals from two (2) or more primary elements or transmitters.
- B.12.2 Multivariable instruments are controllers that receive input signals from two (2) or more primary elements or transmitters and control one (1) manipulated variable.


- B.12.3 Multifunction instruments are controllers that receive input signals from two (2) or more primary elements or transmitters and control two (2) or more manipulated variables.
- B.12.4 Single variable or multivariable multipoint recorders for two (2) or three (3) points are drawn with bubbles either:
 - a) Tangent to each other in the same order, left to right, as the pen or pointer assignments:





b) Separate from each other with pen number indicated and a note defining the multipoint instrument:




- B.12.5 Multipoint indicators and recorders for four (4) or more points are drawn with bubbles separate from each other, with point number indicated by adding a suffix to the tag numbers:
 - a) Single variable:













b) Multivariable:








B.12.6 A multivariable controller example drawn with bubbles for each measured variable input, the output to the final control element, and measured variable indicators:




B.12.7 variable multifunction controller example drawn with bubbles for measured variable inputs, controller and indicator functions, and final control elements, for example:




- B.13 An example of instrument, functional, and electrical diagrams for a simple process
- B.13.1 Process control description:
 - a) Process description:
 - 1) Tank periodically fills with a liquid, in small and large volumes over long and short time periods.
 - b) Control description:
 - 1) Control system design for:
 - a) Small volumes for long and short periods should allow tank to fill to a high level to automatically start the pump and then to stop the pump at a low level.
 - b) Large volumes for long periods should allow the pump to run continuously and maintain a fixed level with a level to flow cascade control loop.

- 2) Pump control is selected by a three-position Hand-Off-Auto selector switch:
 - a) Method a) selector switch is in "HAND" position.
 - b) Method b) selector switch is in "AUTO" position.
- 3) Pump should be stopped at any time:
 - a) Automatically if low level is exceeded.
 - b) By operating the stop pushbutton.
 - c) Switching the H-O-A selector to "OFF" position.


B.13.2 Instrument diagram:



B.13.3 Functional diagram



B.13.4 Electrical schematic diagram:



Developing and promulgating sound consensus standards, recommended practices, and technical reports is one of ISA's primary goals. To achieve this goal the Standards and Practices Department relies on the technical expertise and efforts of volunteer committee members, chairmen and reviewers.

ISA is an American National Standards Institute (ANSI) accredited organization. ISA administers United States Technical Advisory Groups (USTAGs) and provides secretariat support for International Electrotechnical Commission (IEC) and International Organization for Standardization (ISO) committees that develop process measurement and control standards. To obtain additional information on the Society's standards program, please write:

ISA Attn: Standards Department 67 Alexander Drive P.O. Box 12277 Research Triangle Park, NC 27709

ISBN: 978-1-936007-29-5